



Certification

Manufacturer: Larson Electronics LLC
Address: 9419 US-HWY 175
Kemp, Texas 75143

Declare the following equipment conforms to the standard(s) as listed:

Model: EPL-SLSW Series
Description: Explosion Proof Selector Switches

Evaluated Listings:

UL: E12379- NEC / United States standards

UL: E12379 - CEC / Canada standards

CSA: IECEx CSA 19 0030U – IEC Ex / International Standards

CSA: Sira 19ATEX1171U – ATEX / European Standards

ETL: Modifications to enclosure under UL 1203, UL 508A – NEC / United States standards

ETL: Modifications to enclosure under CSA C22.2 No. 14, No. 30, No. 25– CEC / Canadian standards

The EPL-SLSW Series is certified to NEC, CEC, ATEX, and IEC Ex standards for hazardous locations for:

- NEC: Class I, Divisions 1&2, Groups B, C, D; Class II, Divisions 1&2, Groups E, F, G; Class III, Divisions 1 & 2
- CEC: Class I, Divisions 1&2, Groups B, C, D; Class II, Divisions 1&2, Groups E, F, G; Class III, Divisions 1 & 2
- ATEX: II 2G Ex db IIC Gb; II 2D Ex tb IIIC Db; IP66W
- IEC Ex: II 2G Ex db IIC Gb; II 2D Ex tb IIIC Db; IP66W

The EPL-SLSW Series is comprised of a Killark GZ Series switch body assembly. This device may be modified with custom exterior colored switch handles, device label, and mounting accessories, custom mounting of electronics, wire connections. This assembly is built to NEC and CEC standards for hazardous locations.

Signed for and on behalf of: Larson Electronics, LLC
Place of issue: Kemp, TX

Signature: *James Thomas*

Name: James Thomas
Position: Operations Manager