



Certification

Manufacturer: Larson Electronics LLC
Address: 9419 US-HWY 175
Kemp, Texas 75143

Declare the following equipment conforms to the standard(s) as listed:

Model: EXP-XX-LE6 Series
Description: Explosion Proof Light

Evaluated Listings:

UL: FTRV.E83969, BGYM.E83969, FTRX.E150827 – NEC / United States standards

UL: FTRV.E83969, BGYM7.E83969, FTRX7.E150827 – CEC / Canada standards

UL: DEMKO 06 ATEX 141023X, DEMKO 06 ATEX 0521635X – ATEX standards

UL: IEC Ex UL 14.0060X, IEC Ex UL 14.0069X – IEC Ex standards

CSA: LR11716 – CEC / Canada standards

The EXP-XX-LE6 is certified to NEC, CEC, ATEX, and IEC Ex standards for hazardous locations for:

- NEC: Class I, Divisions 1&2, Groups B, C, D; Class II, Divisions 1&2, Groups E, F, G
- NEC: Class I, Zones 1 & 2, Groups IIB + H2, IIA
- CEC: Class I, Divisions 1&2, Groups B, C, D; Class II, Divisions 1&2, Groups E, F, G
- CEC: Class I, Zones 1 & 2, Groups IIB + H2, IIA
- ATEX: Ex II 2 G D, $-60^{\circ}\text{C} \leq T_a \leq +70^{\circ}\text{C}$
- IEC EX: Ex db IIC "T4...T3" Gb, Ex e IIC "T4...T3" Gb, Ex tb IIIC "T110°C...T140°C" Db IP66, $-60^{\circ}\text{C} \leq T_a \leq +70^{\circ}\text{C}$

The EXP-XX-LE6 is comprised of a Killark HK series device enclosure. This device enclosure contains a light assembly, custom mounting of the lights and battery, wire connections, and an aluminum mounting bracket for the enclosure. Emergency models (sku contains "EMG") contain a UL 924 certified emergency light assembly and power supply. This assembly is built to NEC, CEC, ATEX, and IEC standards for hazardous locations.

Signed for and on behalf of: Larson Electronics, LLC
Place of issue: Kemp, TX

Signature:

Name: James Thomas
Position: Operations Manager