

480V 3PH 200A Disconnect
Installed 3X2000A Time Delay Fuses



208Y/120V to 480V 3PH 150KVA Transformer

208Y/120V 3PH 500A Main Panel

480V 3PH 200A Disconnect

150 KVA XFMR

500 A Main Panel
208Y/120V 3PH



20A
20A
450A
20A
20A

500A
Main

Feeder

Neutral

Ground

Title MPD-208Y.120V-150KVA-480V-4X20A.120V		
Author David Downs		
File	Document	
Revision 1.0	Date 06/28/2016	Sheets 1 of 1