

Explosion Proof Conduit Plug INSTALLATION SHEET



CAUTION:

Before installing, make sure you are compliant with area classifications, failure to do so may result in bodily injury, death and property damage. Do not attempt installation until you are familiar with the following procedures. All installation must comply with the applicable Electrical Code.

Make sure that the circuit is de-energized before starting installation or maintenance.

Verify that the installation is grounded. Failure to ground will create electrical shock hazards, which can cause serious injury and or death.

IMPORTANT:

Please read these instructions carefully before installing or maintaining this equipment. Good electrical practices should be followed at all times and this data should be used as a guide only.

Technical information, advice and recommendations contained in these documents is based upon information that Larson Electronics believes to be reliable. All the information and advice contained in these documents is intended for use only by persons having been trained and possessing the requisite skill and know-how and to be used by such persons only at their own discretion and risk. The nature of these instructions is informative only and does not cover all of the details, variations or combinations in which this equipment may be used, its storage, delivery, installation, check out, safe operation and maintenance. Since conditions of use of the product are outside of the care, custody and control of Larson Electronics, the purchaser should determine the suitability of the product for his intended use, and assumes all risk and liability whatsoever in connection therewith.

PART I : Normal Application : For use in Class I, Groups C & D, Class II, Groups E, F & G and Class III Hazardous Locations.

The EPJ-PLUG series conduit plug standard application: to plug existing conduit hub holes in explosion proof enclosures for Groups C & D requires minimum of six threads (turns) engagement to comply with the UL/CSA Standards requirements.

The design of the EPJ-PLUG series conduit plugs has been updated with additional features.

The proper assembly of the cover and body, requires minimum of eight (8) threads (turns) engagement, to be suitable for Class I, II, III Groups C, D, E, F and G.

It is the responsibility of the installer to confirm that the above thread engagement is met, when installing the unit in Group "B" Hazardous Classified Locations.

SHOULD FURTHER INFORMATION NOT COVERED BY THESE INSTRUCTIONS BE REQUIRED, PLEASE CONTACT LARSON ELECTRONICS BY EMAIL AT SALES@LARSONELECTRONICS.COM OR BY PHONE AT 1-800-369-6671 FOR FURTHER ASSISTANCE.