WAL-SL-1000WMH
Replacement Polycarbonate Lens for WAL Series 1000 Watt Metal Halide Portable Light Towers

WARNING
To avoid the risk of fire, explosion or electric shock, this product should be installed, inspected and maintained by a qualified electrician only, in accordance with all applicable electrical codes.

To avoid electric shock:

- Be certain electrical power is OFF before and during installation and maintenance.
- Luminaire must be connected to a wiring system with an equipment-grounding conductor.
- Make sure the supply voltage is within the luminaires' voltage rating.

REPLACING LENS



1. To replace the lens, loosen the screw to remove the outer ring holding the lens.
2. Carefully remove the outer ring, lens and rubber seal.
3. Collect replacement lens and gasket assembly.
4. Replace the gasket, lens and outer ring. Tighten the outer ring screw until snug. Do not over tighten.

MAINTENANCE
Caution: To avoid personal injury, disconnect power to the light and allow the unit to cool down before performing maintenance.

Perform visual, mechanical and electrical inspections on a regular basis. We recommend routine checks to be made on a yearly basis. Frequency of use and environment should determine this. It is recommended to follow an Electrical Preventive Maintenance Program as described in NFPA 70B: Recommended practice for Electrical Equipment.

WARRANTY
Should further information not covered by these instructions be required, please contact Larson Electronics at 1-800-369-6671 or sales@larsonelectronics.com for further assistance.

Please visit LarsonElectronics.com for **Warranty** and **Return** information.