

CERTIFICATE OF COMPLIANCE

Certificate Number 20170907-E83969
Report Reference E83969-19871112
Issue Date 2017-SEPTEMBER-07

Issued to: KILLARK, DIV OF HUBBELL INC (DELAWARE)
3940 MARTIN LUTHER KING DR
ST LOUUIS MO 63113

**This is to certify that
representative samples of**

Enclosures for Use in Class I, Groups B, C, and D;
Class II, Groups E, F and G, Models EXB and EXBLT,
followed by P or C, followed by three numbers, may be
followed by -N34, -SPM, -MOD, -N4, -N4X, and/or -N4XTL.

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety: UL 1203, Explosion-Proof and Dust-Ignition-Proof Electrical
Equipment for Use in Hazardous (Classified) Locations.
CSA C22.2 No. 25-M1966, Enclosures for Use in Class II
Groups E, F, and G Hazardous Locations (R2014).
CAN/CSA C22.2 No. 30-M1986, Explosion-Proof
Enclosures for Use in Class I Hazardous Locations

Additional Information: See the UL Online Certifications Directory at
www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's
Certification and Follow-Up Service.

Look for the UL Certification Mark on the product



Bruce Mahrenholz, Director North American Certification Program
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please
contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

