

RROR.E23572 - Receptacles with Plugs for Use in Hazardous Locations

Receptacles with Plugs for Use in Hazardous Locations

See General Information for Receptacles with Plugs for Use in Hazardous Locations

KILLARK, DIV OF HUBBELL INC (DELAWARE)

E23572

2112 FENTON LOGISTICS PARK BLVD
FENTON, MO 63026 USA

Class I, Groups C and D.

Series KRJ-20 receptacles and Type KP-20A, -20B, -20C plugs. Rated 115 or 230 v, 1 hp, 20 amp, 60 cy, Cat. Nos. KRAJC-120, -220, -320, KRAJT-120, -220, -320, KRJC-120, -220, KRJE-120, -220, KRJL-120, -220, KRJT-120, -220, KRJX-120, -220. All with or without suffix SU37, SU38, SU78, with or without S81.

Series KRJ-30 receptacles and Type KP-30D, -30E plugs. Rated 460 v, ac, 1/2 hp, 7 amp, 115 or 230 v, ac, 1-1/2 hp, 30 amp, 60 cy, single-phase, Cat. Nos. KRAJC-130-3, -230-3, -330-3, KRAJT-130-3, -230-3, -330-3, KRJC-130-3, -230-3, KRJE-130-3, -230-3, KRJL-130-3, -230-3, KRJT-130-3, -230-3, KRJX-130-3, -230-3. All with or without suffix SU37 or SU38, SU78. 460 v, ac, 1 hp, 7 amp, 115 or 230 v, ac, 3 hp, 30 amp, 60 cy, three-phase. Cat. Nos. KRAJC-130-4, -230-4, -330-4, KRAJT-130-4, -230-4, -330-4, KRJC-130-4, -230-4, KRJE-130-4, -230-4, KRJL-130-4, -230-4, KRJT-130-4, -230-4, KRJX-130-4, -230-4. All with or without suffix SU37, SU38, SU78, with or without S81.

Series KRS-30 receptacles and Type KP-30D, -30E, plugs. Rated 460 v, ac, 1/2 hp, 7 amp, 115 or 230 v, ac, 1-1/2 hp, 30 amp, 60 cy, single-phase, Cat. Nos. KRS-13, -14, -41, -42, -43, -44, -45, -46 followed by 303, with or without suffix SU37, SU38, SU78. Rated 460 v, ac, 1 hp, 7 amp, 115 or 230 v, ac, 3 hp, 30 amp, 60 cy, three-phase, Cat. Nos. KRS-13, -14, -41, -42, -43, -44, -45, -46 followed by 304, with or without suffix SU37, SU38, SU78, with or without suffix S81.

Type KRJ-60 receptacles and Type KP-60 plugs. Rated 60 A, 480 vac, 60 cy, three-phase: Receptacle Cat. Nos. KRAJAC-46, -56, -66 followed by 04, followed by suffix SU-37 or SU-38; Cat. Nos. KRAJAE-46, -56, -66 followed by 04, followed by suffix SU-37 or SU-38; Cat. Nos. KRAJAT-46, -56, -66 followed by 04, followed by SU-37 or SU-38; Cat. Nos. KRJX-26, -36 followed by 04, followed by SU-37 or SU-38, followed by S-81, for use with Plug Cat. No. KP-604 followed by suffix SU-37 or SU-38, followed by S81 or SU-78.

Type KRJ-60 receptacles and Type KP-60 plugs. Rated 60 A, 480 vac, 60 cy, single-phase: Receptacle Cat. Nos. KRAJAC-46, -56, -66 followed by 03, followed by suffix SU-37 or SU-38; Cat. Nos. KRAJAE-46, -56, -66 followed by 03, followed by suffix SU-37 or SU-38; Cat. Nos. KRAJAT-46, -56, -66 followed by 03, followed by SU-37 or SU-38; Cat. Nos. KRJX-26, -36 followed by 03, followed by SU-37 or SU-38 followed by S-81, for use with Plug Cat. No. KP-603 followed by suffix SU-37 or SU-38, followed by S81 or SU-78.

Class I, Group D.

Series KRS-20 receptacles and Type KP-20A, -20B, -20C plugs. Rated 115 or 230 v, 1 hp, 20 amp, 60 cy, Cat. Nos. 2KRS-215-120, -215-220, -215-320, -218-120, -218-220, -218-320, KRS-215-120, -215-220, -215-320, -218-120, -220, -320. All with or without suffix SU37, SU38, SU78, with or without S81.

Series KRS-30 receptacles and Type KP-30D, -30E Plugs. Rated 460 v, ac, 1/2 hp, 7 amp, 115 or 230 v, ac, 1-1/2 hp, 30 amp, 60 cy single-phase, Cat. Nos. KRS-17, -215-1, -215-2, -215-3, -218-1, -218-2, -218-3 followed by 303, rated 460 v, ac, 1 hp, 2 amp, 115 or 230 v, ac, 360, 30 amp, 60 cy, three-phase, Cat. Nos. KRS-17, -215-1, -215-2, -215-3, -216-1, -216-2, -216-3 followed by 304, with or without suffix SU37, SU38, SU78, with or without S81.

Type KRJ-60 receptacles and Type KP-60 plugs. Rated 60 A, 480 vac, 60 cy, three-phase: Receptacle Cat. Nos. KRJX-46, -56 followed by 04, followed by suffix SU-37 or SU-38, followed by S81, for use with Plug Cat. No. KP-604 followed by suffix SU-37 or SU-38, followed by S81 or SU-78.

Type KRJ-60 receptacles and Type KP-60 plugs. Rated 60 A, 480 vac, 60 cy, single-phase: Receptacle Cat. Nos. KRJX-46, -56 followed by 03, followed by suffix SU-37 or SU-38, followed by S81, for use with Plug Cat. No. KP-604 followed by suffix SU-37 or SU-38, followed by S81 or SU-78.

(Mailing address: P. O. Box 5325, St. Louis, MO 63115)

Last Updated on 2001-09-24

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from UL" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "© 2021 UL LLC"