



Certificate of Compliance

Certificate: 1923697

Master Contract: 151933

Project: 1923697

Date Issued: 2007/09/03

Issued to: Killark Electric Manufacturing Co.

3940 Martin Luther King Dr
St. Louis, MO 63113
USA
Attention: Tom Michalski

The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US'



Issued by: Matthew Brock

Authorized by: Patricia Pasemko, Operations Manager

PRODUCTS

CLASS 3428 83 - FIXTURES AND FITTINGS - For Hazardous Locations-Certified to U.S. Standards

CLASS 3428 03 - FIXTURES AND FITTINGS - For Hazardous Locations

Class I, Zone 2, [A]Ex nR IIC, T4, T3 or T2, CSA Enclosure Type 4X, IP67, -40 DegC to +65 DegC

Class I, Division 2, Groups ABCD, T1, T2 or T2A

KFS, KFH and KFP MariGard Luminaires, followed by 10, 15, 17, 25, 32, 35, or 40; followed by 0, 5, 6, 7, 8 or

The 'C' and 'US' indicators adjacent to the CSA Mark signify that the product has been evaluated to the applicable CSA and ANSI/UL Standards, for use in Canada and the U.S., respectively. This 'US' indicator includes products eligible to bear the 'NRTL' indicator. NRTL, i.e. National Recognized Testing Laboratory, is a designation granted by the U.S. Occupational Safety and Health Administration (OSHA) to laboratories which have been recognized to perform certification to U.S. Standards.



Certificate: 1923697

Master Contract: 151933

Project: 1923697

Date Issued: 2007/09/03

9; followed by SS; may be followed by nR; may be followed by F1 to F8, may be followed by P1 to P3.

Series KFS, KFH, KFP and KFM, rated 600 V max, 50 & 60 HZ, 400 W max HPS, MH, MHP and MV.

APPLICABLE REQUIREMENTS

The following standards were used as a guide in the evaluation of the products covered by this report.

CSA Standard C22.2 No 0-M1991	-	General Requirements – Canadian Electrical Code Part II.
CAN/CSA E60079-0:07 General requirements	-	Electrical apparatus for explosive gas atmospheres. PART 0:
CAN/CSA E60079-15:02 Electrical Apparatus with type of Protection ‘n’	-	Electrical apparatus for explosive gas atmospheres. PART 15:
CSA Standard C22.2 No 137-M1981	-	Electric Luminaires for Use in Hazardous Locations
ANSI/UL 1598:2004	-	Luminaires
ANSI/UL 595:1991	-	Standard for Marine-Type Electric Lighting Fixtures
ANSI/UL 844:2006 (Classified) Locations	-	Standard for Electric Lighting Fixtures for Use in Hazardous
ANSI/UL 60079-0:2005 General Requirements	-	Electrical Apparatus for Explosive Gas Atmospheres. PART 0:
ANSI/UL 60079-15:2002 Apparatus with Type of Protection “n”	-	Electrical Apparatus for Explosive Gas Atmospheres. PART 15: Electrical