

QPKX.E30252 - Portable Luminaires for Use in Hazardous Locations

Portable Luminaires for Use in Hazardous Locations

See General Information for Portable Luminaires for Use in Hazardous Locations

DANIEL WOODHEAD CO

E30252

2222 WELLINGTON CT
LISLE, IL 60532 USA

Portable lighting units having lamp compartments of explosion-proof construction and sealed from terminal compartments which have provision for connection of three-conductor, flexible cord for extra hard usage.

Class I, Groups C and D; Class II, Groups F and G.

Cat. No. 1080-HZ12, 13W, 12Vac or dc (PL13 fluorescent lamp).

Cat. No. 1080-HZ, 13W, 120Vac (PL-13 fluorescent lamp).

Cat. No. 1090-HZ, 26W, 120Vac (PLC 26 W fluorescent lamp).

Cat. No. 1090-HZ12, 26W, 14.5Vac, 12Vdc. (PLC 26W fluorescent lamp).

Cat. No. 61430CFL, 25W, 120V, (A21 or smaller).

Cat. No. 61430LED, 10W, 120-250V, (A21 or smaller).

Cat. No. 61450; 21W, 120V (LED).

Cat. No. 61440-MH, 50 W metal halide (M110 lamp), 120V.

Cat. Nos. 1070-HZ35, -HZ50, -HZ70, -HZ70MH, -HZ100, may be followed by G.

Class I, Groups C and D.

Cat. No. 61430, 100W max., 250V (A21 or smaller).

Cat. Nos. 1635-6A, 1635-6B, 1635-12A, 1635-12B, 100W max., 120V (A21 or smaller).

Cat. No. 1655-12, Class 2 LED Module

Cat. No. 1070-HZ150.

Class II, Groups F and G.

Cat. No. 61430, 75W (A21 or smaller) max.250V.

Cat. Nos. 1635-6A, 1635-6B, 1635-12A, 1635-12B, 75W (A21 or smaller) max., 120V.

Cat. No. 1655-12, Class 2 LED Module

Class I, Groups C and D; Class II, Group F.

Cat. No. 1070-HZ.

Last Updated on 2015-12-02

The appearance of a company's name or product in this database does not in itself assure that products so identified have been

manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from UL" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "© 2020 UL LLC"