


REV	DESCRIPTION	DATE
A	QUOTE	06/09/2025

MPD-CW1-BS.20AB-DE15YT-CF-2.L40-10.U2.N09-M1

LARSON ELECTRONICS®








CONNECT ALL THE GOUNDS TO THE GROUND BAR

LARSON ELECTRONICS

9419 E US HWY 175,
KEMP, TX 75143

TITLE			
MPD-CW1-BS.20AB-DE15YT-CF-2.L40-10.U2.N09-M1			
DRAWN BY	DATE	REV	
L.Calib	06-09-2025	A	
CHECKED BY	SHEET #	DRAWING #	
	1 OF 3	101	



LARSON ELECTRONICS

9419 E US HWY 175,
KEMP, TX 75143

TITLE: MPD-CW1-BS.20AB-DE15YT-CF-2.L40-10.U2.N09-M1			
DRAWN BY: L.Calib	DATE: 06-09-2025	REV: A	
CHECKED BY:	SHEET #: 2 OF 3	DRAWING #: 102	

TAGS	QTY	CATALOG	DESCRIPTION
J1-101.37 J1-101.47	2		HBL3769 TWIST-LOCK RECEPTACLE, 600V, 50A, 3PH, 3P4W
2 HOLE GRND LUG	1	UNV00007136	2 HOLE GROUND LUG
J2-102.07 J2-102.15 J2-102.23 J2-102.31 J2-102.39 J2-102.47 J2-102.54 J2-102.67 J2-102.74 J2-102.81	10	UNV00007174	5-20R NEMA DUPLX RECEPTACLE
CB1-101.37 CB1-101.47	2	UNV00015175	250V 50A 3P UL489 MINIATURE CIRCUIT BREAKER
CB1-101.08	1	UNV00017567	UTE100E FTU 20A 3P LL UL489 MCCB (14kA/600V, 25kA/480V, 50kA/240V)
CB2-102.07 CB2-102.15 CB2-102.23 CB2-102.31 CB2-102.39 CB2-102.47 CB2-102.54 CB2-102.67 CB2-102.74 CB2-102.81	10	UNV00019330	1P+1N 120V 20A DIN RAIL MOUNT GROUND FAULT CIRCUIT BREAKER UL1053
CB1-101.08A	1	UNV00015176	3P 50A 240/480VAC MCCB
PD 1	1	UNV00016633	POWER DISTRIBUTION BLOCK 380A 1-6 OPENING
PD 2 PD 3 PD 4	3	UNV00015084	POWER DISTRIBUTION BLOCK 175 A 600V 1-4 OPENING
GRND BAR KIT	1	UNV00013942C	GROUND BAR KIT
CBL1-101.08	1	UNV00007438	12/4 SOOW CABLE
XF1-101.11	1	UNV00019201	480D TO 208Y/120V 15KVA TRANSFORMER

LARSON ELECTRONICS
9419 E US HWY 175,
KEMP, TX 75143

TITLE: MPD-CW1-BS.20AB-DE15YT-CF-2.L40-10.U2.N09-M1

DRAWN BY	DATE	REV
L.Calib	06-09-2025	A
CHECKED BY	SHEET #	DRAWING #
	3 OF 3	103