

EPL-SLSW-3P-1.0.1

Explosion Proof Selector Switch - 600V AC - 3-position Switch - Short Barrel - 1/0/1 Nameplate
Product ID: 148550



Larson Electronics LLC manufactures a wide variety of products, including custom built to spec designs. The pictures displayed for this unit are a general representation of form factor for the product line and may not accurately represent this exact configuration in every detail due to custom builds and changes between similar products in our standard catalog. The specifics for this configuration are listed in the specification table and supporting documentation (CAD files, Dimensional Drawing, Name Plate Diagram, Wiring Diagram, etc.). This means that specific details (receptacles, plugs, wires, connections, mounting brackets, external finishes, etc.) may not be accurately represented in images vs specifications. Please review specifications and do not order based solely on images.

EPL-SLSW-3P-1.0.1 Explosion Proof Selector Switch

Unit Type: Explosion Proof Selector Switch

Dimensions: 4" - L, 1.75" - Diameter

Weight: 2 lbs

Voltage Rating: 600V AC

Amps: 10A @ 120-600V AC, 2.5A @ 125/250V DC

Positions: 3 (Left, Center, Right)

Operation: Maintained Switch

Switch Type: SPST

Operating Temp: -50°C to +60°C

Materials: Aluminum and Stainless Steel

Contact Configuration: 1NO, 1NC

Nameplate Marking: 1/0/1

Ratings/Approvals

Class I, Divisions 1 & 2 Groups C,D

Class I, Zones 1 & 2 Groups IIB,IIA

Class II, Divisions 1 & 2 Groups E,F,G

Class III

NEMA 3, 4, 4X, 7 (B,C,D) 9 (E,F,G)

Special Orders- Requirements

Contact us for special requirements

Toll Free: 1-800-369-6671

Intl: 1-214-616-6180

Fax: 1-903-498-3364

E-mail: sales@larsonelectronics.com

The EPL-SLSW-3P-1.0.1 from Larson Electronics is an Explosion Proof Selector Switch that is suitable for preventing the ignition of external, flammable atmospheres in hazardous locations. This 600V-rated unit features a short barrel design with maintained operation and supports three positions (left, center, right). The explosion proof device comes with a 1/0/1 nameplate marking and is designed for 1/2" thick walls.

The EPL-SLSW-3P-1.0.1 is rated for Class I, Divisions 1 & 2; Class I, Zones 1 & 2; Class II, Divisions 1 & 2; and Class III facilities. The maintained contact switch comes with a maximum rating of 600V AC and features a total of three positions (left, center, right). A 1/0/1 nameplate marking ensures visibility and reduces human error during operation. For protection in hazardous locations, the explosion proof device is constructed of aluminum and stainless steel. During installation, this selector switch is compatible with wall thickness measurements of 1/2".

Applications: Chemical processing facilities, food processing plants, oil refineries, agricultural sites, grain storage facilities, metal processing and more. At Larson Electronics, we do more than meet your lighting needs. We also provide replacement, retrofit, and upgrade parts as well as industrial grade power accessories. Our craftsmen can custom build any lighting system and/or accessories to fit the unique demands of your operation. A commitment to honesty, quality, and dependability has made Larson Electronics a leader in the lighting and electronics business since 1973. Contact us today at 800-369-6671 or message sales@larsonelectronics.com for more information about our custom options tailored to meet your specific industry needs.



Certification

Manufacturer: Larson Electronics LLC
Address: 9419 US-HWY 175
Kemp, Texas 75143

Declare the following equipment conforms to the standard(s) as listed:

Model: EPL-SLSW Series
Description: Explosion Proof Selector Switches

Evaluated Listings:

UL: E12379- NEC / United States standards

UL: E12379 - CEC / Canada standards

CSA: IECEx CSA 19 0030U – IEC Ex / International Standards

CSA: Sira 19ATEX1171U – ATEX / European Standards

ETL: Modifications to enclosure under UL 1203, UL 508A – NEC / United States standards

ETL: Modifications to enclosure under CSA C22.2 No. 14, No. 30, No. 25– CEC / Canadian standards

The EPL-SLSW Series is certified to NEC, CEC, ATEX, and IEC Ex standards for hazardous locations for:

- NEC: Class I, Divisions 1&2, Groups B, C, D; Class II, Divisions 1&2, Groups E, F, G; Class III, Divisions 1 & 2
- CEC: Class I, Divisions 1&2, Groups B, C, D; Class II, Divisions 1&2, Groups E, F, G; Class III, Divisions 1 & 2
- ATEX: II 2G Ex db IIC Gb; II 2D Ex tb IIIC Db; IP66W
- IEC Ex: II 2G Ex db IIC Gb; II 2D Ex tb IIIC Db; IP66W

The EPL-SLSW Series is comprised of a Killark GZ Series switch body assembly. This device may be modified with custom exterior colored switch handles, device label, and mounting accessories, custom mounting of electronics, wire connections. This assembly is built to NEC and CEC standards for hazardous locations.

Signed for and on behalf of: Larson Electronics, LLC
Place of issue: Kemp, TX

Signature:

Name: James Thomas
Position: Operations Manager

[<- Back](#)

Product Description

Title: INDUSTRIAL CONTROL PANELS

Company: LARSON ELECTRONICS LLC - Kemp, TX USA

Product Information: Industrial Control Panels For General Use.

Evaluated to the following: A representative sample of the listed devices have been tested, investigated and found to comply with the requirements of the Standard(s) for Industrial Control Panels (UL-508A) and are identified with the ETL Listed Mark.

[<- Back](#)

Contact Us

ETL listed products that are in doubt or for products that do not appear in the directory, please request a verification of certification.
Americas+1-888-347-5478
(or +1-847-660-7407)
Email
etldirectory@intertek.com

[Intertek Home](#)
[Product Directories](#)
[DLP on mobile devices](#)

Inspector Center

Get up-to-date information on everything from our Accreditations to our Certifications and Marks. [Learn more...](#)

News

Intertek Unveils New Design for Product Safety and Quality Certification Marks. [Learn more...](#)

© 2010 Intertek All Rights Reserved.
All other product or service names are the property of their respective owners.

[<- Back](#)

Product Description

Title: EXPLOSION-PROOF & DUST IGNITION-PROOF ELECTRICAL EQUIPMENT FOR USE IN HAZARDOUS (CLASSIFIED) LOCATIONS

Company: LARSON ELECTRONICS LLC - Kemp, TX USA

Product Information: Explosion-proof or dust-ignition-proof Industrial Control Panels for use in Hazardous (Classified) Locations, Model Nos. Custom Industrial Control Panels

Evaluated to the following: A representative sample of the listed devices have been tested, investigated and found to comply with the requirements of the Standard(s) for Explosion-Proof and Dust Ignition-Proof Electrical Equipment for Use in Hazardous (Classified) Locations (UL-1203) and are identified with the ETL Listed Mark.

[<- Back](#)

Contact Us

ETL listed products that are in doubt or for products that do not appear in the directory, please request a verification of certification.
Americas+1-888-347-5478
(or +1-847-660-7407)
Email
etldirectory@intertek.com

[Intertek Home](#)
[Product Directories](#)
[DLP on mobile devices](#)

Inspector Center

Get up-to-date information on everything from our Accreditations to our Certifications and Marks. [Learn more...](#)

News

Intertek Unveils New Design for Product Safety and Quality Certification Marks. [Learn more...](#)

© 2010 Intertek All Rights Reserved.
All other product or service names are the property of their respective owners.

[<- Back](#)

Product Description

Title: INDUSTRIAL CONTROL EQUIPMENT
Company: LARSON ELECTRONICS LLC - Kemp, TX USA
Product Information: Industrial Control Panels For General Use.
Industrial Control Panels Relating to Hazardous (Classified) Locations, Custom Industrial Control Panels.

Power Distribution System, Model Nos. MGL, MPD, MGS series;
Followed by AAK-PBB.FFF-SCC.GGG-EEXCCC.DDD; Where AA = 2,3,5,7,9,15,20,25,30,45,50,75; BB = 1P, 3P; FFF = 480,240,208,120; CC = 1P,3P; GGG = 480,240,208,120; EE = # of outlets; CCC = voltage; DDD = outlet amperage.

Evaluated to the following: A representative sample of the listed devices have been tested, investigated and found to comply with the requirements of the Standard(s) for Industrial Control Equipment (CAN/CSA-C22.2 No. 14) and are identified with the cETL Listed Mark.

[<- Back](#)

Contact Us

ETL listed products that are in doubt or for products that do not appear in the directory, please request a verification of certification.
Americas+1-888-347-5478
(or +1-847-660-7407)
Email
etldirectory@intertek.com

[Intertek Home](#)
[Product Directories](#)
[DLP on mobile devices](#)

Inspector Center

Get up-to-date information on everything from our Accreditations to our Certifications and Marks. [Learn more...](#)

News

Intertek Unveils New Design for Product Safety and Quality Certification Marks. [Learn more...](#)

© 2010 Intertek All Rights Reserved.
All other product or service names are the property of their respective owners.

[<- Back](#)

Product Description

Title: ENCLOSURES
Company: LARSON ELECTRONICS LLC - Kemp, TX USA
Product Information: Explosion-proof or dust-ignition-proof Industrial Control Panels for use in Hazardous (Classified) Locations, Model Nos. Custom Industrial Control Panels

Luminaires, Model Nos. EPL-48-2L-LED-SFC, EPL-24-2L-LED-SFC. for use in Hazardous Locations: Class I, Div. 1, Groups C and D T5 or T6 -20°C < Tamb < 40°C Class II, Div. 1., Groups E, F, and G; Class III Div.1 T3B -20°C < Tamb < 40°C

Evaluated to the following: A representative sample of the listed devices have been tested, investigated and found to comply with the requirements of the Standard(s) for Enclosures for use in Class II, Groups E, F, G Hazardous Locations (CAN/CSA-C22.2 No. 25) and are identified with the cETL Listed Mark.

[<- Back](#)

Contact Us

ETL listed products that are in doubt or for products that do not appear in the directory, please request a verification of certification.
Americas+1-888-347-5478
(or +1-847-660-7407)
Email
etldirectory@intertek.com

[Intertek Home](#)
[Product Directories](#)
[DLP on mobile devices](#)

Inspector Center

Get up-to-date information on everything from our Accreditations to our Certifications and Marks. [Learn more...](#)

News

Intertek Unveils New Design for Product Safety and Quality Certification Marks. [Learn more...](#)

© 2010 Intertek All Rights Reserved.
All other product or service names are the property of their respective owners.

[<- Back](#)

Product Description

Title: EXPLOSION-PROOF ENCLOSURES FOR USE IN CLASS I HAZARDOUS LOCATIONS

Company: LARSON ELECTRONICS LLC - Kemp, TX USA

Product Information: Explosion-proof or dust-ignition-proof Industrial Control Panels for use in Hazardous (Classified) Locations, Model Nos. Custom Industrial Control Panels

Evaluated to the following: A representative sample of the listed devices have been tested, investigated and found to comply with the requirements of the Standard(s) for Explosion-Proof Enclosures for Use in Class I Hazardous Locations (CAN/CSA-C22.2 No. 30) and are identified with the cETL Listed Mark.

[<- Back](#)

Contact Us

ETL listed products that are in doubt or for products that do not appear in the directory, please request a verification of certification.
Americas+1-888-347-5478
(or +1-847-660-7407)
Email
etldirectory@intertek.com

[Intertek Home](#)
[Product Directories](#)
[DLP on mobile devices](#)

Inspector Center

Get up-to-date information on everything from our Accreditations to our Certifications and Marks. [Learn more...](#)

News

Intertek Unveils New Design for Product Safety and Quality Certification Marks. [Learn more...](#)

© 2010 Intertek All Rights Reserved.
All other product or service names are the property of their respective owners.



Material Safety Data Sheet

To Whom It May Concern,

The Larson Electronics LLC EPL-SLSW industrial line of explosion proof switches and controls for hazardous locations are considered “ARTICLES” under 29 CFR 1910-1200, the OSHA Hazard Communication Standard, and do not require a Material Safety Data Sheet (MSDS). This document does not expire.

Articles are specifically exempt from the regulations of this standard. OSHA defines an article as follows:

1910-1200(c) – Article means a manufactured item other than a fluid or particle:

- i. Which is formed to a specific shape or design during manufacture;
- ii. Which has end use function(s) dependent in whole or in part upon its shape or design during end use; and
- iii. Which under normal conditions does not release more than very small quantities.

The “hazardous location” and “explosion proof” are terminology for the environment where these products will be installed. This is not to be confused with “hazardous materials;” this product does not contain any hazardous materials.

Regards,

Ray Smith
Larson Electronics, LLC.

CERTIFICATE OF COMPLIANCE

Certificate Number 20191107-E12379
Report Reference E12379-20191015
Issue Date 2019-NOVEMBER-07

Issued to: KILLARK, DIV OF HUBBELL INC (DELAWARE)
2112 FENTON LOGISTICS PARK BLVD
FENTON, MO 63026 USA

**This certificate confirms that
representative samples of**

AUXILIARY DEVICES FOR USE IN HAZARDOUS
LOCATIONS

Please see Addendum for Models

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.


Standard(s) for Safety:
Additional Information:

Please see Addendum for Standards for Safety
See the UL Online Certifications Directory at
<https://iq.ulprospector.com> for additional information.

This *Certificate of Compliance* does not provide authorization to apply the UL Mark. Only the UL Follow-Up Services Procedure provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



CERTIFICATE OF COMPLIANCE

Certificate Number 20191107-E12379
Report Reference E12379-20191015
Issue Date 2019-NOVEMBER-07

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Industrial Control Devices, for Use in Class I, Division 1, Groups B, C, and D; Class II, Division 1, Groups E, F and G; Class III; Hazardous (Classified) Locations, Models

GZ21-RZ3, GZ21-GZ3, GZ21-KZ3, GZ21-AZ3, GZ21-WZ3, GZ21-BZ3, GZ1-RX3, GZ1-GX3, GZ1-KX3, GZ1-AX3, GZ1-WX3, GZ1-BX3, GZL1R3, GZL1G3, GZL1K3, GZL1A3, GZL1W3, GZL1B3, GZ21B-RZ3, GZ21B-GZ3, GZ21B-KZ3, GZ21B-AZ3, GZ21B-WZ3, GZ21B-BZ3, GZ1B-RX3, GZ1B-GX3, GZ1B-KX3, GZ1B-AX3, GZ1B-WX3, GZ1B-BX3, GZLB1R3, GZLB1G3, GZLB1K3, GZLB1A3, GZLB1W3, GZLB1B3, GZ23-G23, GZB3-G23, GZL3G23, GZ23-R23, GZB3-R23, GZL3R23, GZ23-A23, GZB3-A23, GZL3A23, GZ23-C23, GZB3-C23, GZL3C23, GZ23-B23, GZB3-B23, GZL3B23, GZ23-G4, GZB3-G4, GZL3G4, GZ23-R4, GZB3-R4, GZL3R4, GZ23-A4, GZB3-A4, GZL3A4, GZ23-C4, GZB3-C4, GZL3C4, GZ23-B4, GZB3-B4, GZL3B4, GZ23-G24, GZB3-G24, GZL3G24, GZ23-R24, GZB3-R24, GZL3R24, GZ23-A24, GZB3-A24, GZL3A24, GZ23-C24, GZB3-C24, GZL3C24, GZ23-B24, GZB3-B24, GZL3B24, GZMM21-RY3, GZMM1-RY3, GZMML-RY3, GZMM21-RG3, GZMM1-RG3, GZMML-RG3, GZMM21-RB3, GZMM1-RB3, GZMML-RB3, GZMP21-RM3, GZMP1-RM3, GZMPL1R3, GZMP21-GM3, GZMP1-GM3, GZMPL1G3, GZMP21-KM3, GZMP1-KM3, GZMPL1K3, GZMT21-RM3, GZMT1-RM3, GZMTL1R3, GZMK21-RM3, GZMK1-RM3, GZMKL1R3, GZK21-3, GZK1-3, GZKL13, GZ24-G233, GZB4-G233, GZL4G233, GZ24-R233, GZB4-R233, GZL4R233, GZ24-A233, GZB4-A233, GZL4A233, GZ24-B233, GZB4-B233, GZL4B233, GZ24-C233, GZB4-C233, GZL4C233, GZ24-G43, GZB4-G43, GZL4G43, GZ24-R43, GZB4-R43, GZL4R43, GZ24-A43, GZB4-A43, GZL4A43, GZ24-B43, GZB4-B43, GZL4B43, GZ24-C43, GZB4-C43, GZL4C43, GZ24-G243, GZB4-G243, GZL4G243, GZ24-R243, GZB4-R243, GZL4R243, GZ24-A243, GZB4-A243, GZL4A243, GZ24-B243, GZB4-B243, GZL4B243, GZ24-C243, GZB4-C243, GZL4C243, GZ25-2A3, GZ5-2A3, GZL52A3, GZ25-3C3, GZ5-3C3, GZL53C3, GZ25-3G3, GZ5-3G3, GZL53G3, GZ25-4H8, GZ5-4H8, GZL54H8, GZ25-2A6, GZ5-2A6, GZL52A6, GZ25-2A8, GZ5-2A8, GZL52A8, GZ25-3C8, GZ5-3C8, GZL53C8, GZ25-3G8, GZ5-3G8, GZL53G8, GZ25-4H88, GZ5-4H88, GZL54H88, GZ28-2A3, GZ8-2A3, GZL82A3, GZ28-3C3, GZ8-3C3, GZL83C3, GZ28-3G3, GZ8-3G3, GZL83G3, GZ28-4H8, GZ8-4H8, GZL84H8, GZ28-2A6, GZ8-2A6, GZL82A6, GZ28-2A8, GZ8-2A8, GZL82A8, GZ28-3C8, GZ8-3C8, GZL83C8, GZ28-3G8, GZ8-3G8, GZL83G8, GZ28-4H88, GZ8-4H88, GZL84H88, GZ26-3, GZ6-3, GZL63, GZ35-6, GZ15-6, GZL156, GZ27-6, GZ7-6, GZL76, GZ34-6, GZ14-6, GZL146, GZ56-2L3, GZ36-2L3, GZL36L3, GZ59-3R6, GZ39-3R6, GZL39R6, GZ57-3C6, GZ37-3C6, GZL37C6, GZ58-3L6, GZ38-3L6, GZL38L6, GZDS25-3232, GZDS5-3232, GZLDS5-3232, GZDS25-3240, GZDS5-3240, GZLDS5-3240, GZDS25-3263, GZDS5-3263, GZLDS5-3263, GZDS25-4232, GZDS5-4232, GZLDS5-4232, GZDS25-4240, GZDS5-4240, GZLDS5-4240, GZDS25-4263, GZDS5-4263, GZLDS5-4263, GZ21-RZ3-M, GZ21-GZ3-M, GZ21-KZ3-M, GZ21-AZ3-M, GZ21-WZ3-M, GZ21-BZ3-M, GZ1-RX3-M, GZ1-GX3-M, GZ1-KX3-M, GZ1-AX3-M, GZ1-WX3-M, GZ1-BX3-M, GZL1R3-M, GZL1G3-M, GZL1K3-M, GZL1A3-M, GZL1W3-M, GZL1B3-M, GZ21B-RZ3-M, GZ21B-GZ3-M, GZ21B-KZ3-M, GZ21B-AZ3-M, GZ21B-WZ3-M, GZ21B-BZ3-M, GZ1B-RX3-M, GZ1B-GX3-M, GZ1B-KX3-M, GZ1B-AX3-M, GZ1B-WX3-M,

B. Mahrenholz

Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



CERTIFICATE OF COMPLIANCE

Certificate Number 20191107-E12379
Report Reference E12379-20191015
Issue Date 2019-NOVEMBER-07

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Industrial Control Devices, for Use in Class I, Division 1, Groups B, C, and D; Class II, Division 1, Groups E, F and G; Class III; Hazardous (Classified) Locations, Models

GZ1B-BX3-M, GZLB1R3-M, GZLB1G3-M, GZLB1K3-M, GZLB1A3-M, GZLB1W3-M, GZLB1B3-M, GZ23-G23-M, GZB3-G23-M, GZL3G23-M, GZ23-R23-M, GZB3-R23-M, GZL3R23-M, GZ23-A23-M, GZB3-A23-M, GZL3A23-M, GZ23-C23-M, GZB3C23-M, GZL3C23-M, GZ23-B23-M, GZB3-B23-M, GZL3B23-M, GZ23-G4-M, GZB3-G4-M, GZL3G4-M, GZ23-R4-M, GZB3-R4-M, GZL3R4-M, GZ23-A4-M, GZB3-A4-M, GZL3A4-M, GZ23-C4-M, GZB3-C4-M, GZL3C4-M, GZ23-B4-M, GZB3-B4-M, GZL3B4-M, GZ23-G24-M, GZB3-G24-M, GZL3G24-M, GZ23-R24-M, GZB3-R24-M, GZL3R24-M, GZ23-A24-M, GZB3-A24-M, GZL3A24-M, GZ23-C24-M, GZB3-C24-M, GZL3C24-M, GZ23-B24-M, GZB3-B24-M, GZL3B24-M, GZMM21-RY3-M, GZMM1-RY3-M, GZMML-RY3-M, GZMM21-RG3-M, GZMM1-RG3-M, GZMML-RG3-M, GZMM21-RB3-M, GZMM1-RB3-M, GZMML-RB3-M, GZMP21-RM3-M, GZMP1-RM3-M, GZMPL1R3-M, GZMP21-GM3-M, GZMP1-GM3-M, GZMPL1G3-M, GZMP21-KM3-M, GZMP1-KM3-M, GZMPL1K3-M, GZMT21-RM3-M, GZMT1-RM3-M, GZMTL1R3-M, GZMK21-RM3-M, GZMK1-RM3-M, GZMKL1R3-M, GZK21-3-M, GZK1-3-M, GZKL13-M, GZ24-G233-M, GZB4-G233-M, GZL4G233-M, GZ24-R233-M, GZB4-R233-M, GZL4R233-M, GZ24-A233-M, GZB4-A233-M, GZL4A233-M, GZ24-B233-M, GZB4-B233-M, GZL4B233-M, GZ24-C233-M, GZB4-C233-M, GZL4C233-M, GZ24-G43-M, GZB4-G43-M, GZL4G43-M, GZ24-R43-M, GZB4-R43-M, GZL4R43-M, GZ24-A43-M, GZB4-A43-M, GZL4A43-M, GZ24-B43-M, GZB4-B43-M, GZL4B43-M, GZ24-C43-M, GZB4-C43-M, GZL4C43-M, GZ24-G243-M, GZB4-G243-M, GZL4G243-M, GZ24-R243-M, GZB4-R243-M, GZL4R243-M, GZ24-A243-M, GZB4-A243-M, GZL4A243-M, GZ24-B243-M, GZB4-B243-M, GZL4B243-M, GZ24-C243-M, GZB4-C243-M, GZL4C243-M, GZ25-2A3-M, GZ5-2A3-M, GZL52A3-M, GZ25-3C3-M, GZ5-3C3-M, GZL53C3-M, GZ25-3G3-M, GZ5-3G3-M, GZL53G3-M, GZ25-4H8-M, GZ5-4H8-M, GZL54H8-M, GZ25-2A6-M, GZ5-2A6-M, GZL52A6-M, GZ25-2A8-M, GZ5-2A8-M, GZL52A8-M, GZ25-3C8-M, GZ5-3C8-M, GZL53C8-M, GZ25-3G8-M, GZ5-3G8-M, GZL53G8-M, GZ25-4H88-M, GZ5-4H88-M, GZL54H88-M, GZ28-2A3-M, GZ8-2A3-M, GZL82A3-M, GZ28-3C3-M, GZ8-3C3-M, GZL83C3-M, GZ28-3G3-M, GZ8-3G3-M, GZL83G3-M, GZ28-4H8-M, GZ8-4H8-M, GZL84H8-M, GZ28-2A6-M, GZ8-2A6-M, GZL82A6-M, GZ28-2A8-M, GZ8-2A8-M, GZL82A8-M, GZ28-3C8-M, GZ8-3C8-M, GZL83C8-M, GZ28-3G8-M, GZ8-3G8-M, GZL83G8-M, GZ28-4H88-M, GZ8-4H88-M, GZL84H88-M, GZ26-3-M, GZ6-3F-M, GZL63-M, GZ35-6-M, GZ15-6-M, GZL156-M, GZ27-6-M, GZ7-6-M, GZL76-M, GZ34-6-M, GZ14-6-M, GZL146-M, GZ56-2L3-M, GZ36-2L3-M, GZL36L3-M, GZ59-3R6-M, GZ39-3R6-M, GZL39R6-M, GZ57-3C6-M, GZ37-3C6-M, GZL37C6-M, GZ58-3L6-M, GZ38-3L6-M, GZL38L6-M, GZDS25-3232-M, GZDS5-3232-M, GZLDS5-3232-M, GZDS25-3240-M, GZDS5-3240-M, GZLDS5-3240-M, GZDS25-3263-M, GZDS5-3263-M, GZLDS5-3263-M, GZDS25-4232-M, GZDS5-4232-M, GZLDS5-4232-M, GZDS25-4240-M, GZDS5-4240-M, GZLDS5-4240-M, GZDS25-4263-M, GZDS5-4263-M, GZLDS5-4263-M

B. Mahrenholz

Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



CERTIFICATE OF COMPLIANCE

Certificate Number 20191107-E12379
Report Reference E12379-20191015
Issue Date 2019-NOVEMBER-07

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Standard(s) for Safety: UL 1203 - Explosion-Proof and Dust-Ignition-Proof Electrical Equipment for Use in Hazardous (Classified) Locations.


CAN/CSA C22.2 No. 30-M1986 - Explosion-Proof Enclosures for Use in Class I Hazardous Locations. Reaffirmed 2016

CAN/CSA C22.2 No. 25-1966 - Enclosures for Use in Class II Groups E, F, and G Hazardous Locations. Reaffirmed 2014.

UL 50 - Enclosures for electrical equipment

UL 508 & CSA C22.2 no. 14-13 - Standard for industrial control equipment

CSA C22.2 no. 94-M91 - Special purpose enclosures industrial product



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



CERTIFICATE OF COMPLIANCE

Certificate Number 20191107-E12379
Report Reference E12379-20191015
Issue Date 2019-NOVEMBER-07

Issued to: KILLARK, DIV OF HUBBELL INC (DELAWARE)
2112 FENTON LOGISTICS PARK BLVD
FENTON, MO 63026 USA

**This certificate confirms that
representative samples of**

AUXILIARY DEVICES FOR USE IN HAZARDOUS
LOCATIONS

Please see Addendum for Models

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.


Standard(s) for Safety:
Additional Information:

Please see Addendum for Standards for Safety
See the UL Online Certifications Directory at
<https://iq.ulprospector.com> for additional information.

This *Certificate of Compliance* does not provide authorization to apply the UL Mark. Only the UL Follow-Up Services Procedure provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



CERTIFICATE OF COMPLIANCE

Certificate Number 20191107-E12379
Report Reference E12379-20191015
Issue Date 2019-NOVEMBER-07

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Industrial Control Devices, for Use in Class I, Division 1, Groups B, C, and D; Class II, Division 1, Groups E, F and G; Class III; Hazardous (Classified) Locations, Models

GZ21-RZ3, GZ21-GZ3, GZ21-KZ3, GZ21-AZ3, GZ21-WZ3, GZ21-BZ3, GZ1-RX3, GZ1-GX3, GZ1-KX3, GZ1-AX3, GZ1-WX3, GZ1-BX3, GZL1R3, GZL1G3, GZL1K3, GZL1A3, GZL1W3, GZL1B3, GZ21B-RZ3, GZ21B-GZ3, GZ21B-KZ3, GZ21B-AZ3, GZ21B-WZ3, GZ21B-BZ3, GZ1B-RX3, GZ1B-GX3, GZ1B-KX3, GZ1B-AX3, GZ1B-WX3, GZ1B-BX3, GZLB1R3, GZLB1G3, GZLB1K3, GZLB1A3, GZLB1W3, GZLB1B3, GZ23-G23, GZB3-G23, GZL3G23, GZ23-R23, GZB3-R23, GZL3R23, GZ23-A23, GZB3-A23, GZL3A23, GZ23-C23, GZB3-C23, GZL3C23, GZ23-B23, GZB3-B23, GZL3B23, GZ23-G4, GZB3-G4, GZL3G4, GZ23-R4, GZB3-R4, GZL3R4, GZ23-A4, GZB3-A4, GZL3A4, GZ23-C4, GZB3-C4, GZL3C4, GZ23-B4, GZB3-B4, GZL3B4, GZ23-G24, GZB3-G24, GZL3G24, GZ23-R24, GZB3-R24, GZL3R24, GZ23-A24, GZB3-A24, GZL3A24, GZ23-C24, GZB3-C24, GZL3C24, GZ23-B24, GZB3-B24, GZL3B24, GZMM21-RY3, GZMM1-RY3, GZMML-RY3, GZMM21-RG3, GZMM1-RG3, GZMML-RG3, GZMM21-RB3, GZMM1-RB3, GZMML-RB3, GZMP21-RM3, GZMP1-RM3, GZMPL1R3, GZMP21-GM3, GZMP1-GM3, GZMPL1G3, GZMP21-KM3, GZMP1-KM3, GZMPL1K3, GZMT21-RM3, GZMT1-RM3, GZMTL1R3, GZMK21-RM3, GZMK1-RM3, GZMKL1R3, GZK21-3, GZK1-3, GZKL13, GZ24-G233, GZB4-G233, GZL4G233, GZ24-R233, GZB4-R233, GZL4R233, GZ24-A233, GZB4-A233, GZL4A233, GZ24-B233, GZB4-B233, GZL4B233, GZ24-C233, GZB4-C233, GZL4C233, GZ24-G43, GZB4-G43, GZL4G43, GZ24-R43, GZB4-R43, GZL4R43, GZ24-A43, GZB4-A43, GZL4A43, GZ24-B43, GZB4-B43, GZL4B43, GZ24-C43, GZB4-C43, GZL4C43, GZ24-G243, GZB4-G243, GZL4G243, GZ24-R243, GZB4-R243, GZL4R243, GZ24-A243, GZB4-A243, GZL4A243, GZ24-B243, GZB4-B243, GZL4B243, GZ24-C243, GZB4-C243, GZL4C243, GZ25-2A3, GZ5-2A3, GZL52A3, GZ25-3C3, GZ5-3C3, GZL53C3, GZ25-3G3, GZ5-3G3, GZL53G3, GZ25-4H8, GZ5-4H8, GZL54H8, GZ25-2A6, GZ5-2A6, GZL52A6, GZ25-2A8, GZ5-2A8, GZL52A8, GZ25-3C8, GZ5-3C8, GZL53C8, GZ25-3G8, GZ5-3G8, GZL53G8, GZ25-4H88, GZ5-4H88, GZL54H88, GZ28-2A3, GZ8-2A3, GZL82A3, GZ28-3C3, GZ8-3C3, GZL83C3, GZ28-3G3, GZ8-3G3, GZL83G3, GZ28-4H8, GZ8-4H8, GZL84H8, GZ28-2A6, GZ8-2A6, GZL82A6, GZ28-2A8, GZ8-2A8, GZL82A8, GZ28-3C8, GZ8-3C8, GZL83C8, GZ28-3G8, GZ8-3G8, GZL83G8, GZ28-4H88, GZ8-4H88, GZL84H88, GZ26-3, GZ6-3, GZL63, GZ35-6, GZ15-6, GZL156, GZ27-6, GZ7-6, GZL76, GZ34-6, GZ14-6, GZL146, GZ56-2L3, GZ36-2L3, GZL36L3, GZ59-3R6, GZ39-3R6, GZL39R6, GZ57-3C6, GZ37-3C6, GZL37C6, GZ58-3L6, GZ38-3L6, GZL38L6, GZDS25-3232, GZDS5-3232, GZLDS5-3232, GZDS25-3240, GZDS5-3240, GZLDS5-3240, GZDS25-3263, GZDS5-3263, GZLDS5-3263, GZDS25-4232, GZDS5-4232, GZLDS5-4232, GZDS25-4240, GZDS5-4240, GZLDS5-4240, GZDS25-4263, GZDS5-4263, GZLDS5-4263, GZ21-RZ3-M, GZ21-GZ3-M, GZ21-KZ3-M, GZ21-AZ3-M, GZ21-WZ3-M, GZ21-BZ3-M, GZ1-RX3-M, GZ1-GX3-M, GZ1-KX3-M, GZ1-AX3-M, GZ1-WX3-M, GZ1-BX3-M, GZL1R3-M, GZL1G3-M, GZL1K3-M, GZL1A3-M, GZL1W3-M, GZL1B3-M, GZ21B-RZ3-M, GZ21B-GZ3-M, GZ21B-KZ3-M, GZ21B-AZ3-M, GZ21B-WZ3-M, GZ21B-BZ3-M, GZ1B-RX3-M, GZ1B-GX3-M, GZ1B-KX3-M, GZ1B-AX3-M, GZ1B-WX3-M,

B. Mahrenholz

Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



CERTIFICATE OF COMPLIANCE

Certificate Number 20191107-E12379
Report Reference E12379-20191015
Issue Date 2019-NOVEMBER-07

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Industrial Control Devices, for Use in Class I, Division 1, Groups B, C, and D; Class II, Division 1, Groups E, F and G; Class III; Hazardous (Classified) Locations, Models

GZ1B-BX3-M, GZLB1R3-M, GZLB1G3-M, GZLB1K3-M, GZLB1A3-M, GZLB1W3-M, GZLB1B3-M, GZ23-G23-M, GZB3-G23-M, GZL3G23-M, GZ23-R23-M, GZB3-R23-M, GZL3R23-M, GZ23-A23-M, GZB3-A23-M, GZL3A23-M, GZ23-C23-M, GZB3C23-M, GZL3C23-M, GZ23-B23-M, GZB3-B23-M, GZL3B23-M, GZ23-G4-M, GZB3-G4-M, GZL3G4-M, GZ23-R4-M, GZB3-R4-M, GZL3R4-M, GZ23-A4-M, GZB3-A4-M, GZL3A4-M, GZ23-C4-M, GZB3-C4-M, GZL3C4-M, GZ23-B4-M, GZB3-B4-M, GZL3B4-M, GZ23-G24-M, GZB3-G24-M, GZL3G24-M, GZ23-R24-M, GZB3-R24-M, GZL3R24-M, GZ23-A24-M, GZB3-A24-M, GZL3A24-M, GZ23-C24-M, GZB3-C24-M, GZL3C24-M, GZ23-B24-M, GZB3-B24-M, GZL3B24-M, GZMM21-RY3-M, GZMM1-RY3-M, GZMML-RY3-M, GZMM21-RG3-M, GZMM1-RG3-M, GZMML-RG3-M, GZMM21-RB3-M, GZMM1-RB3-M, GZMML-RB3-M, GZMP21-RM3-M, GZMP1-RM3-M, GZMPL1R3-M, GZMP21-GM3-M, GZMP1-GM3-M, GZMPL1G3-M, GZMP21-KM3-M, GZMP1-KM3-M, GZMPL1K3-M, GZMT21-RM3-M, GZMT1-RM3-M, GZMTL1R3-M, GZMK21-RM3-M, GZMK1-RM3-M, GZMKL1R3-M, GZK21-3-M, GZK1-3-M, GZKL13-M, GZ24-G233-M, GZB4-G233-M, GZL4G233-M, GZ24-R233-M, GZB4-R233-M, GZL4R233-M, GZ24-A233-M, GZB4-A233-M, GZL4A233-M, GZ24-B233-M, GZB4-B233-M, GZL4B233-M, GZ24-C233-M, GZB4-C233-M, GZL4C233-M, GZ24-G43-M, GZB4-G43-M, GZL4G43-M, GZ24-R43-M, GZB4-R43-M, GZL4R43-M, GZ24-A43-M, GZB4-A43-M, GZL4A43-M, GZ24-B43-M, GZB4-B43-M, GZL4B43-M, GZ24-C43-M, GZB4-C43-M, GZL4C43-M, GZ24-G243-M, GZB4-G243-M, GZL4G243-M, GZ24-R243-M, GZB4-R243-M, GZL4R243-M, GZ24-A243-M, GZB4-A243-M, GZL4A243-M, GZ24-B243-M, GZB4-B243-M, GZL4B243-M, GZ24-C243-M, GZB4-C243-M, GZL4C243-M, GZ25-2A3-M, GZ5-2A3-M, GZL52A3-M, GZ25-3C3-M, GZ5-3C3-M, GZL53C3-M, GZ25-3G3-M, GZ5-3G3-M, GZL53G3-M, GZ25-4H8-M, GZ5-4H8-M, GZL54H8-M, GZ25-2A6-M, GZ5-2A6-M, GZL52A6-M, GZ25-2A8-M, GZ5-2A8-M, GZL52A8-M, GZ25-3C8-M, GZ5-3C8-M, GZL53C8-M, GZ25-3G8-M, GZ5-3G8-M, GZL53G8-M, GZ25-4H88-M, GZ5-4H88-M, GZL54H88-M, GZ28-2A3-M, GZ8-2A3-M, GZL82A3-M, GZ28-3C3-M, GZ8-3C3-M, GZL83C3-M, GZ28-3G3-M, GZ8-3G3-M, GZL83G3-M, GZ28-4H8-M, GZ8-4H8-M, GZL84H8-M, GZ28-2A6-M, GZ8-2A6-M, GZL82A6-M, GZ28-2A8-M, GZ8-2A8-M, GZL82A8-M, GZ28-3C8-M, GZ8-3C8-M, GZL83C8-M, GZ28-3G8-M, GZ8-3G8-M, GZL83G8-M, GZ28-4H88-M, GZ8-4H88-M, GZL84H88-M, GZ26-3-M, GZ6-3F-M, GZL63-M, GZ35-6-M, GZ15-6-M, GZL156-M, GZ27-6-M, GZ7-6-M, GZL76-M, GZ34-6-M, GZ14-6-M, GZL146-M, GZ56-2L3-M, GZ36-2L3-M, GZL36L3-M, GZ59-3R6-M, GZ39-3R6-M, GZL39R6-M, GZ57-3C6-M, GZ37-3C6-M, GZL37C6-M, GZ58-3L6-M, GZ38-3L6-M, GZL38L6-M, GZDS25-3232-M, GZDS5-3232-M, GZLDS5-3232-M, GZDS25-3240-M, GZDS5-3240-M, GZLDS5-3240-M, GZDS25-3263-M, GZDS5-3263-M, GZLDS5-3263-M, GZDS25-4232-M, GZDS5-4232-M, GZLDS5-4232-M, GZDS25-4240-M, GZDS5-4240-M, GZLDS5-4240-M, GZDS25-4263-M, GZDS5-4263-M, GZLDS5-4263-M

B. Mahrenholz

Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



CERTIFICATE OF COMPLIANCE

Certificate Number 20191107-E12379
Report Reference E12379-20191015
Issue Date 2019-NOVEMBER-07

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Standard(s) for Safety: UL 1203 - Explosion-Proof and Dust-Ignition-Proof Electrical Equipment for Use in Hazardous (Classified) Locations.


CAN/CSA C22.2 No. 30-M1986 - Explosion-Proof Enclosures for Use in Class I Hazardous Locations. Reaffirmed 2016

CAN/CSA C22.2 No. 25-1966 - Enclosures for Use in Class II Groups E, F, and G Hazardous Locations. Reaffirmed 2014.

UL 50 - Enclosures for electrical equipment

UL 508 & CSA C22.2 no. 14-13 - Standard for industrial control equipment

CSA C22.2 no. 94-M91 - Special purpose enclosures industrial product



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>





Certification

Manufacturer: Larson Electronics LLC
Address: 9419 US-HWY 175
Kemp, Texas 75143

Declare the following equipment conforms to the standard(s) as listed:

Model: EPL-SLSW Series
Description: Explosion Proof Selector Switches

Evaluated Listings:

CE: DIRECTIVE 2014/35/EU - LOW VOLTAGE DIRECTIVE
CE: DIRECTIVE 2014/30/EU - EMC DIRECTIVE
CE: Regulation (EC) No 1907/2006 - REACH REGULATION
CE: DIRECTIVE 2015/863/EU - ROHS DIRECTIVE

The EPL-SLSW Series complies with the essential protection requirements of the European Parliament of the Council Directive for Low Voltage Directive, EMC Directive, REACH Regulation, and RoHS Directive. This certification applies to all specimens manufactured in accordance to the manufacture's drawings.

Signed for and on behalf of: Larson Electronics, LLC
Place of issue: Kemp, TX

Signature: *James Thomas*

Name: James Thomas
Position: Operations Manager



Certification

Manufacturer: Larson Electronics LLC
Address: 9419 US-HWY 175
Kemp, Texas 75143

Declare the following equipment conforms to the standard(s) as listed:

Model: EPL-SLSW Series
Description: Explosion Proof Selector Switches

Evaluated Listings:

CE: DIRECTIVE 2015/863/EU - ROHS DIRECTIVE

This is to certify that products offered by Larson Electronics LLC comply with the Reduction of Hazardous Substances (RoHS) directives. Directive 2002/95/EC became effective on 1 July 2006. It restricts the use of six substances in the manufacture of electrical and electronic equipment. This directive was revised in June 2011 and is now referred to as directive 2011/65/EU. Directive 2015/863/EU amending Annex II to Directive 2011/65/EU announced plans to add four substances from 22 July 2019.

We hereby certify that the equipment specified above conforms to the Directive(s) by containing less of the restricted substances than the stated limits.

Signed for and on behalf of: Larson Electronics, LLC
Place of issue: Kemp, TX

Signature: *James Thomas*

Name: James Thomas
Position: Operations Manager



Certification

Manufacturer: Larson Electronics LLC
Address: 9419 US-HWY 175
Kemp, Texas 75143

Declare the following equipment conforms to the standard(s) as listed:

Model: EPL-SLSW Series
Description: Explosion Proof Selector Switches

Evaluated Listings:

CE: Regulation (EC) No 1907/2006 - REACH REGULATION

This letter establishes the opinion of Larson Electronics LLC regarding the status, under the current European Union ("EU") Regulations on Registration, Evaluation, Authorization, and Restriction of Chemical Substances ("REACH").

REACH does not apply to manufactured products which are referred to as "completed articles". Substances (chemicals) are subject to REACH registration, NOT products.

In addition, Articles are exempt from the REACH requirements if (a) the Article does not contain a substance of very high concern or candidate substance in an amount exceeding 0.1% weight by weight, and (b) if substances present in the Article in excess of 1 ton per year per importer are not expected nor intended to be released.

Based on communication with our raw material suppliers, we conclude that to the best of our knowledge our products requiring REACH compliance do not contain any of the currently listed SVHC in concentrations of 0.1% or above.

Accordingly, we foresee no registration or pre-registration requirement for the products we supply.

Signed for and on behalf of: Larson Electronics, LLC
Place of issue: Kemp, TX

Signature: *James Thomas*

Name: James Thomas
Position: Operations Manager



Certification

Manufacturer: Larson Electronics LLC
Address: 9419 US-HWY 175
Kemp, Texas 75143

Declare the following equipment conforms to the standard(s) as listed:

Model: EPL-SLSW Series
Description: Explosion Proof Selector Switches

Evaluated Listings:

FCC: Radio Frequency Emission & Authorization Status

The EPL-SLSW Series of Explosion Proof Selector Switches comply with Federal Communications Commission requirements for Radio Frequency Emission & Authorization Status. This product is not capable of emitting rf energy and does not require FCC authorization. This certification applies to all specimens manufactured in accordance to the manufacture's drawings.

Signed for and on behalf of: Larson Electronics, LLC
Place of issue: Kemp, TX

Signature: *James Thomas*

Name: James Thomas
Position: Operations Manager

Frequently Asked Questions (FAQ)