Larson Electronics LLC
9419 E US HWY 175, Kemp, TX 75143
Phone: 800.369.6671

www.LarsonElectronics.com
Email: sales@LarsonElectronics.com
Fax: 903.498.3364

EPCS-PL-LED-120V-A-XL

12mA Explosion Proof LED Pilot Light - Class I, II, III - 120V AC/DC, Long Barrel - Amber - TB - N4X

Product ID: 272098



Larson Electronics LLC manufactures a wide variety of products, including custom built to spec designs. The pictures displayed for this unit are a general representation of form factor for the product line and may not accurately represent this exact configuration in every detail due to custom builds and changes between similar products in our standard catalog. The specifics for this configuration are listed in the specification table and supporting documentation (CAD files, Dimensional Drawing, Name Plate Diagram, Wiring Diagram, etc.). This means that specific details (receptacles, plugs, wires, connections, mounting brackets, external finishes, etc.) may not be accurately represented in images vs specifications. Please review specifications and do not order based solely on images.

EPCS-PL-LED-120V-A-XL Extended LED Pilot Light
Listing: NRTL Listed for United States, Canada, Europe, International
Unit Type: Explosion Proof Pilot Light
Dimensions: 4.2" x 1.8" x 1.8"
Weight: 0.25 lbs
Voltage Rating: 120V AC/DC
Frequency: 50/60 Hz
Watts: 1.5W
Amp Rating: 12mA
LED Lifespan: 50,000+ Hours
Light Color: Amber
Thread Length: 1.57" (40mm)
Design: Long Barrel
Ambient Operating Temp: -50°C to +60°C
Materials: Aluminum and Stainless Steel
Mount: Surface/Panel
Wiring: Terminal Blocks
Body: 3/4"-14 NPSM Threaded


Ratings/Approvals
Class I, Divisions 1&2 Groups B,C,D
Class II, Divisions 1&2 Groups E,F,G
Class III
ATEX/IECEx Rated
Ex II 2G Ex db IIC Gb
Ex II 2D Ex tb IIIC Db
NEMA 4X
IP66

Special Orders - Special Requirements
Contact us for special requirements

Toll Free: 1-800-369-6671
Intl: 1-903-270-1187
Fax: 1-903-498-3364
E-mail: sales@larsonelectronics.com

The EPCS-PL-LED-120V-A-XL from Larson Electronics is an Explosion Proof LED Pilot Light that is suitable for preventing the ignition of external, flammable atmospheres in combustible sites. This 120V AC/DC unit features a long barrel, threaded design for installation in thick panels. The explosion proof device comes with terminal blocks for wiring

connections.
The EPCS-PL-LED-120V-A-XL is rated for Class I, II and III, as well as ATEX/IECEx rated facilities. This long-barrel unit operates with 120V AC/DC at 12mA. During use, the LED pilot light provides amber output. This NEMA 4X rated device features a 3/4"-14 NPSM threaded body. For protection in hazardous locations, the explosion proof pilot light is constructed of aluminum and stainless steel. The IP66 rated unit features terminal blocks for wiring connections.
LED Benefits: Unlike gas burning and arc type lamps that have glass bulbs, LEDs have no filaments or fragile housings to break during operation. Instead of heating a small filament or using a combination of gases to produce light, light emitting diodes (LEDs) use semi-conductive materials that illuminate when electric current applied and emitting light. With LED lights, there is no warm up time or cool down time before re-striking and provide instant illumination when powered on, adding to the reliability of LED technology. By nature, LED light sources run significantly cooler than traditional lamps, reducing the chance of accidental burns and increased temperatures due to heat emissions. This solid state design of light emitting diodes provides a more reliable, stable, durable, and energy efficient light source over traditional lighting.
Mounting: This pilot light is compatible with panel or surface mounting applications.
Applications: Chemical processing facilities, food processing plants, oil refineries, agricultural sites, grain storage facilities, metal processing and more.
At Larson Electronics, we do more than meet your lighting needs. We also provide replacement, retrofit, and upgrade parts as well as industrial grade power accessories. Our craftsmen can custom build any lighting system and/or accessories to fit the unique demands of your operation. A commitment to honesty, quality, and dependability has made Larson Electronics a leader in the lighting and electronics business since 1973. Contact us today at 800-369-6671 or message sales@larsonelectronics.com for more information about our custom options tailored to meet your specific industry needs.



LARSON ELECTRONICS

TITLE:

EPCS-PL-LED-XX

PROPRIETARY AND CONFIDENTIAL
THE INFORMATION CONTAINED IN THIS DRAWING IS THE SOLE PROPERTY OF LARSON ELECTRONICS LLC. ANY REPRODUCTION IN PART OR AS A WHOLE WITHOUT THE WRITTEN PERMISSION OF LARSON ELECTRONICS LLC IS PROHIBITED.

		NAME
DIMENSIONS ARE IN INCHES	DRAWN	
MATERIAL	CHECKED	JEREMY BLANKENSHIP
DO NOT SCALE DRAWING		

SIZE	DWG. NO.	REV
A		

SHEET 1 OF 1

5 4 3 2 1


L001 SG
Max. 2,6W /250
BA 9s
LISTED
73NF

Certification

Manufacturer: Larson Electronics LLC
Address: 9419 US-HWY 175
Kemp, Texas 75143

Declare the following equipment conforms to the standard(s) as listed:

Model: EPCS-PL-LED Series
Description: Explosion Proof Pilot Lights

Evaluated Listings:

UL: E12379- NEC / United States standards
UL: E12379 - CEC / Canada standards
CSA: IECEx CSA 19 0030U – IEC Ex / International Standards
CSA: Sira 19ATEX1171U – ATEX / European Standards
ETL: Modifications to enclosure under UL 1203, UL 508A – NEC / United States standards
ETL: Modifications to enclosure under CSA C22.2 No. 14, No. 30, No. 25– CEC / Canadian standards

The EPCS-PL-LED Series is certified to NEC, CEC, ATEX, and IEC Ex standards for hazardous locations for:

- NEC: Class I, Divisions 1&2, Groups B, C, D; Class II, Divisions 1&2, Groups E, F, G; Class III, Divisions 1 & 2
- CEC: Class I, Divisions 1&2, Groups B, C, D; Class II, Divisions 1&2, Groups E, F, G; Class III, Divisions 1 & 2
- ATEX: II 2G Ex db IIC Gb; II 2D Ex tb IIIC Db; IP66W
- IEC Ex: II 2G Ex db IIC Gb; II 2D Ex tb IIIC Db; IP66W

The EPCS-PL-LED Series is comprised of a Killark GZ Series pilot light. This device may be modified with custom exterior colored lens, device label, and mounting accessories, custom mounting of electronics, wire connections. This assembly is built to NEC and CEC standards for hazardous locations.

Signed for and on behalf of: Larson Electronics, LLC
Place of issue: Kemp, TX

Signature: James Thomas

Name: James Thomas
Position: Operations Manager

LARSON ELECTRONICS LLC • 9419 E US HWY 175 • KEMP, TX 75143
p: 1-800-369-6671 • intl: 903-498-3363 • f: 903-498-3364 • sales@larsonelectronics.com

intertek
Total Quality. Assured.



<- Back

Product Description

Title:	INDUSTRIAL CONTROL PANELS
Company:	LARSON ELECTRONICS LLC - Kemp, TX USA
Product Information:	Industrial Control Panels For General Use.
Evaluated to the following:	A representative sample of the listed devices have been tested, investigated and found to comply with the requirements of the Standard(s) for Industrial Control Panels (UL-508A) and are identified with the ETL Listed Mark.

<- Back

Contact Us

ETL listed products that are in doubt or for products that do not appear in the directory, please request a verification of certification.
Americas+1-888-347-5478 (or +1-847-660-7407)
Email etldirectory@intertek.com

Intertek Home
Product Directories
DLP on mobile devices

Inspector Center

Get up-to-date information on everything from our Accreditations to our Certifications and Marks. Learn more...

News

Intertek Unveils New Design for Product Safety and Quality Certification Marks. Learn more...

© 2010 Intertek All Rights Reserved.
All other product or service names are the property of their respective owners.

intertek
Total Quality. Assured.



<- Back

Product Description

Title:	EXPLOSION-PROOF & DUST IGNITION-PROOF ELECTRICAL EQUIPMENT FOR USE IN HAZARDOUS (CLASSIFIED) LOCATIONS
Company:	LARSON ELECTRONICS LLC - Kemp, TX USA
Product Information:	Explosion-proof or dust-ignition-proof Industrial Control Panels for use in Hazardous (Classified) Locations, Model Nos. Custom Industrial Control Panels
Evaluated to the following:	A representative sample of the listed devices have been tested, investigated and found to comply with the requirements of the Standard(s) for Explosion-Proof and Dust Ignition-Proof Electrical Equipment for Use in Hazardous (Classified) Locations (UL-1203) and are identified with the ETL Listed Mark.

<- Back

Contact Us

ETL listed products that are in doubt or for products that do not appear in the directory, please request a verification of certification.
Americas+1-888-347-5478 (or +1-847-660-7407)
Email
etldirectory@intertek.com

Intertek Home
Product Directories
DLP on mobile devices

Inspector Center

Get up-to-date information on everything from our Accreditations to our Certifications and Marks. Learn more...

News

Intertek Unveils New Design for Product Safety and Quality Certification Marks. Learn more...

© 2010 Intertek All Rights Reserved.
All other product or service names are the property of their respective owners.

intertek
Total Quality. Assured.

<- Back

Product Description

Title:	INDUSTRIAL CONTROL EQUIPMENT
Company:	LARSON ELECTRONICS LLC - Kemp, TX USA
Product Information:	Industrial Control Panels For General Use. Industrial Control Panels Relating to Hazardous (Classified) Locations, Custom Industrial Control Panels. Power Distribution System, Model Nos. MGL, MPD, MGS series; Followed by AAK-PBB.FFF-SCC.GGG-EEXCCC.DDD; Where AA = 2,3,5,7,9,15,20,25,30,45,50,75; BB = 1P, 3P; FFF = 480,240,208,120; CC = 1P,3P; GGG = 480,240,208,120; EE = # of outlets; CCC = voltage; DDD = outlet amperage.
Evaluated to the following:	A representative sample of the listed devices have been tested, investigated and found to comply with the requirements of the Standard(s) for Industrial Control Equipment (CAN/CSA-C22.2 No. 14) and are identified with the cETL Listed Mark.

<- Back

Contact Us

ETL listed products that are in doubt or for products that do not appear in the directory, please request a verification of certification.
Americas+1-888-347-5478 (or +1-847-660-7407)
Email
etldirectory@intertek.com

Intertek Home
Product Directories
DLP on mobile devices

Inspector Center

Get up-to-date information on everything from our Accreditations to our Certifications and Marks. Learn more...

News

Intertek Unveils New Design for Product Safety and Quality Certification Marks. Learn more...

© 2010 Intertek All Rights Reserved.
All other product or service names are the property of their respective owners.

intertek
Total Quality. Assured.

<- Back

Product Description

Title:	ENCLOSURES
Company:	LARSON ELECTRONICS LLC - Kemp, TX USA
Product Information:	Explosion-proof or dust-ignition-proof Industrial Control Panels for use in Hazardous (Classified) Locations, Model Nos. Custom Industrial Control Panels Luminaires, Model Nos. EPL-48-2L-LED-SFC, EPL-24-2L-LED-SFC. for use in Hazardous Locations: Class I, Div. 1, Groups C and D T5 or T6 -20°C < Tamb < 40°C Class II, Div. 1., Groups E, F, and G; Class III Div.1 T3B -20°C < Tamb < 40°C
Evaluated to the following:	A representative sample of the listed devices have been tested, investigated and found to comply with the requirements of the Standard(s) for Enclosures for use in Class II, Groups E, F, G Hazardous Locations (CAN/CSA-C22.2 No. 25) and are identified with the cETL Listed Mark.

<- Back

Contact Us

ETL listed products that are in doubt or for products that do not appear in the directory, please request a verification of certification.
Americas+1-888-347-5478 (or +1-847-660-7407)
Email etldirectory@intertek.com

Intertek Home
Product Directories
DLP on mobile devices

Inspector Center

Get up-to-date information on everything from our Accreditations to our Certifications and Marks. Learn more...

News

Intertek Unveils New Design for Product Safety and Quality Certification Marks. Learn more...

© 2010 Intertek All Rights Reserved.
All other product or service names are the property of their respective owners.

intertek
Total Quality. Assured.



<- Back

Product Description

Title:	EXPLOSION-PROOF ENCLOSURES FOR USE IN CLASS I HAZARDOUS LOCATIONS
Company:	LARSON ELECTRONICS LLC - Kemp, TX USA
Product Information:	Explosion-proof or dust-ignition-proof Industrial Control Panels for use in Hazardous (Classified) Locations, Model Nos. Custom Industrial Control Panels
Evaluated to the following:	A representative sample of the listed devices have been tested, investigated and found to comply with the requirements of the Standard(s) for Explosion-Proof Enclosures for Use in Class I Hazardous Locations (CAN/CSA-C22.2 No. 30) and are identified with the cETL Listed Mark.

<- Back

Contact Us

ETL listed products that are in doubt or for products that do not appear in the directory, please request a verification of certification.
Americas+1-888-347-5478 (or +1-847-660-7407)
Email
etldirectory@intertek.com

Intertek Home
Product Directories
DLP on mobile devices

Inspector Center

Get up-to-date information on everything from our Accreditations to our Certifications and Marks. Learn more...

News

Intertek Unveils New Design for Product Safety and Quality Certification Marks. Learn more...

© 2010 Intertek All Rights Reserved.
All other product or service names are the property of their respective owners.

Material Safety Data Sheet

To Whom It May Concern,

The Larson Electronics LLC EPCS-PL-LED industrial line of explosion proof LED lights and controls for hazardous locations are considered "ARTICLES" under 29 CFR 1910-1200, the OSHA Hazard Communication Standard, and do not require a Material Safety Data Sheet (MSDS). This document does not expire.

Articles are specifically exempt from the regulations of this standard. OSHA defines an article as follows:

1910-1200(c) – Article means a manufactured item other than a fluid or particle:

i. Which is formed to a specific shape or design during manufacture;
ii. Which has end use function(s) dependent in whole or in part upon its shape or design during end use; and
iii. Which under normal conditions does not release more than very small quantities.

The "hazardous location" and "explosion proof" are terminology for the environment where these products will be installed. This is not to be confused with "hazardous materials;" this product does not contain any hazardous materials.

Regards,

Ray Smith
Larson Electronics, LLC.

LARSON ELECTRONICS LLC • 9419 E US HWY 175 • KEMP, TX 75143
p: 1-800-369-6671 • intl: 903-498-3363 • f: 903-498-3364 • sales@larsonelectronics.com

CERTIFICATE OF COMPLIANCE

Certificate Number	20191107-E12379
Report Reference	E12379-20191015
Issue Date	2019-NOVEMBER-07
Issued to:	KILLARK, DIV OF HUBBELL INC (DELAWARE) 2112 FENTON LOGISTICS PARK BLVD FENTON, MO 63026 USA
This certificate confirms that representative samples of	AUXILIARY DEVICES FOR USE IN HAZARDOUS LOCATIONS Please see Addendum for Models
	Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.
Standard(s) for Safety:	Please see Addendum for Standards for Safety
Additional Information:	See the UL Online Certifications Directory at https://iq.ulprospector.com for additional information.

This *Certificate of Compliance* does not provide authorization to apply the UL Mark. Only the UL Follow-Up Services Procedure provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.

Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at http://ul.com/aboutul/locations/

CERTIFICATE OF COMPLIANCE

Certificate Number	20191107-E12379
Report Reference	E12379-20191015
Issue Date	2019-NOVEMBER-07

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Industrial Control Devices, for Use in Class I, Division 1, Groups B, C, and D; Class II, Division 1, Groups E, F and G; Class III; Hazardous (Classified) Locations, Models GZ21-RZ3, GZ21-GZ3, GZ21-KZ3, GZ21-AZ3, GZ21-WZ3, GZ21-BZ3, GZ1-RX3, GZ1-GX3, GZ1-KX3, GZ1-AX3, GZ1-WX3, GZ1-BX3, GZL1R3, GZL1G3, GZL1K3, GZL1A3, GZL1W3, GZL1B3, GZ21B-RZ3, GZ21B-GZ3, GZ21B-KZ3, GZ21B-AZ3, GZ21B-WZ3, GZ21B-BZ3, GZ1B-RX3, GZ1B-GX3, GZ1B-KX3, GZ1B-AX3, GZ1B-WX3, GZ1B-BX3, GZLB1R3, GZLB1G3, GZLB1K3, GZLB1A3, GZLB1W3, GZLB1B3, GZ23-G23, GZB3-G23, GZL3G23, GZ23-R23, GZB3-R23, GZL3R23, GZ23-A23, GZB3-A23, GZL3A23, GZ23-C23, GZB3-C23, GZL3C23, GZ23-B23, GZB3-B23, GZL3B23, GZ23-G4, GZB3-G4, GZL3G4, GZ23-R4, GZB3-R4, GZL3R4, GZ23-A4, GZB3-A4, GZL3A4, GZ23-C4, GZB3-C4, GZL3C4, GZ23-B4, GZB3-B4, GZL3B4, GZ23-G24, GZB3-G24, GZL3G24, GZ23-R24, GZB3-R24, GZL3R24, GZ23-A24, GZB3-A24, GZL3A24, GZ23-C24, GZB3-C24, GZL3C24, GZ23-B24, GZB3-B24, GZL3B24, GZMM21-RY3, GZMM1-RY3, GZMML-RY3, GZMM21-RG3, GZMM1-RG3, GZMML-RG3, GZMM21-RB3, GZMM1-RB3, GZMML-RB3, GZMP21-RM3, GZMP1-RM3, GZMPL1R3, GZMP21-GM3, GZMP1-GM3, GZMPL1G3, GZMP21-KM3, GZMP1-KM3, GZMPL1K3, GZMT21-RM3, GZMT1-RM3, GZMTL1R3, GZMK21-RM3, GZMK1-RM3, GZMKL1R3, GZK21-3, GZK1-3, GZKL13, GZ24-G233, GZB4-G233, GZL4G233, GZ24-R233, GZB4-R233, GZL4R233, GZ24-A233, GZB4-A233, GZL4A233, GZ24-B233, GZB4-B233, GZL4B233, GZ24-C233, GZB4-C233, GZL4C233, GZ24-G43, GZB4-G43, GZL4G43, GZ24-R43, GZB4-R43, GZL4R43, GZ24-A43, GZB4-A43, GZL4A43, GZ24-B43, GZB4-B43, GZL4B43, GZ24-C43, GZB4-C43, GZL4C43, GZ24-G243, GZB4-G243, GZL4G243, GZ24-R243, GZB4-R243, GZL4R243, GZ24-A243, GZB4-A243, GZL4A243, GZ24-B243, GZB4-B243, GZL4B243, GZ24-C243, GZB4-C243, GZL4C243, GZ25-2A3, GZ5-2A3, GZL52A3, GZ25-3C3, GZ5-3C3, GZL53C3, GZ25-3G3, GZ5-3G3, GZL53G3, GZ25-4H8, GZ5-4H8, GZL54H8, GZ25-2A6, GZ5-2A6, GZL52A6, GZ25-2A8, GZ5-2A8, GZL52A8, GZ25-3C8, GZ5-3C8, GZL53C8, GZ25-3G8, GZ5-3G8, GZL53G8, GZ25-4H88, GZ5-4H88, GZL54H88, GZ28-2A3, GZ8-2A3, GZL82A3, GZ28-3C3, GZ8-3C3, GZL83C3, GZ28-3G3, GZ8-3G3, GZL83G3, GZ28-4H8, GZ8-4H8, GZL84H8, GZ28-2A6, GZ8-2A6, GZL82A6, GZ28-2A8, GZ8-2A8, GZL82A8, GZ28-3C8, GZ8-3C8, GZL83C8, GZ28-3G8, GZ8-3G8, GZL83G8, GZ28-4H88, GZ8-4H88, GZL84H88, GZ26-3, GZ6-3, GZL63, GZ35-6, GZ15-6, GZL156, GZ27-6, GZ7-6, GZL76, GZ34-6, GZ14-6, GZL146, GZ56-2L3, GZ36-2L3, GZL36L3, GZ59-3R6, GZ39-3R6, GZL39R6, GZ57-3C6, GZ37-3C6, GZL37C6, GZ58-3L6, GZ38-3L6, GZL38L6, GZDS25-3232, GZDS5-3232, GZLDS5-3232, GZDS25-3240, GZDS5-3240, GZLDS5-3240, GZDS25-3263, GZDS5-3263, GZLDS5-3263, GZDS25-4232, GZDS5-4232, GZLDS5-4232, GZDS25-4240, GZDS5-4240, GZLDS5-4240, GZDS25-4263, GZDS5-4263, GZLDS5-4263, GZ21-RZ3-M, GZ21-GZ3-M, GZ21-KZ3-M, GZ21-AZ3-M, GZ21-WZ3-M, GZ21-BZ3-M, GZ1-RX3-M, GZ1-GX3-M, GZ1-KX3-M, GZ1-AX3-M, GZ1-WX3-M, GZ1-BX3-M, GZL1R3-M, GZL1G3-M, GZL1K3-M, GZL1A3-M, GZL1W3-M, GZL1B3-M, GZ21B-RZ3-M, GZ21B-GZ3-M, GZ21B-KZ3-M, GZ21B-AZ3-M, GZ21B-WZ3-M, GZ21B-BZ3-M, GZ1B-RX3-M, GZ1B-GX3-M, GZ1B-KX3-M, GZ1B-AX3-M, GZ1B-WX3-M,

Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at http://ul.com/aboutul/locations/

CERTIFICATE OF COMPLIANCE

Certificate Number	20191107-E12379
Report Reference	E12379-20191015
Issue Date	2019-NOVEMBER-07

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Industrial Control Devices, for Use in Class I, Division 1, Groups B, C, and D; Class II, Division 1, Groups E, F and G; Class III; Hazardous (Classified) Locations, Models GZ1B-BX3-M, GZLB1R3-M, GZLB1G3-M, GZLB1K3-M, GZLB1A3-M, GZLB1W3-M, GZLB1B3-M, GZ23-G23-M, GZB3-G23-M, GZL3G23-M, GZ23-R23-M, GZB3-R23-M, GZL3R23-M, GZ23-A23-M, GZB3-A23-M, GZL3A23-M, GZ23-C23-M, GZB3C23-M, GZL3C23-M, GZ23-B23-M, GZB3-B23-M, GZL3B23-M, GZ23-G4-M, GZB3-G4-M, GZL3G4-M, GZ23-R4-M, GZB3-R4-M, GZL3R4-M, GZ23-A4-M, GZB3-A4-M, GZL3A4-M, GZ23-C4-M, GZB3-C4-M, GZL3C4-M, GZ23-B4-M, GZB3-B4-M, GZL3B4-M, GZ23-G24-M, GZB3-G24-M, GZL3G24-M, GZ23-R24-M, GZB3-R24-M, GZL3R24-M, GZ23-A24-M, GZB3-A24-M, GZL3A24-M, GZ23-C24-M, GZB3-C24-M, GZL3C24-M, GZ23-B24-M, GZB3-B24-M, GZL3B24-M, GZMM21-RY3-M, GZMM1-RY3-M, GZMML-RY3-M, GZMM21-RG3-M, GZMM1-RG3-M, GZMML-RG3-M, GZMM21-RB3-M, GZMM1-RB3-M, GZMML-RB3-M, GZMP21-RM3-M, GZMP1-RM3-M, GZMPL1R3-M, GZMP21-GM3-M, GZMP1-GM3-M, GZMPL1G3-M, GZMP21-KM3-M, GZMP1-KM3-M, GZMPL1K3-M, GZMT21-RM3-M, GZMT1-RM3-M, GZMTL1R3-M, GZMK21-RM3-M, GZMK1-RM3-M, GZMKL1R3-M, GZK21-3-M, GZK1-3-M, GZKL13-M, GZ24-G233-M, GZB4-G233-M, GZL4G233-M, GZ24-R233-M, GZB4-R233-M, GZL4R233-M, GZ24-A233-M, GZB4-A233-M, GZL4A233-M, GZ24-B233-M, GZB4-B233-M, GZL4B233-M, GZ24-C233-M, GZB4-C233-M, GZL4C233-M, GZ24-G43-M, GZB4-G43-M, GZL4G43-M, GZ24-R43-M, GZB4-R43-M, GZL4R43-M, GZ24-A43-M, GZB4-A43-M, GZL4A43-M, GZ24-B43-M, GZB4-B43-M, GZL4B43-M, GZ24-C43-M, GZB4-C43-M, GZL4C43-M, GZ24-G243-M, GZB4-G243-M, GZL4G243-M, GZ24-R243-M, GZB4-R243-M, GZL4R243-M, GZ24-A243-M, GZB4-A243-M, GZL4A243-M, GZ24-B243-M, GZB4-B243-M, GZL4B243-M, GZ24-C243-M, GZB4-C243-M, GZL4C243-M, GZ25-2A3-M, GZ5-2A3-M, GZL52A3-M, GZ25-3C3-M, GZ5-3C3-M, GZL53C3-M, GZ25-3G3-M, GZ5-3G3-M, GZL53G3-M, GZ25-4H8-M, GZ5-4H8-M, GZL54H8-M, GZ25-2A6-M, GZ5-2A6-M, GZL52A6-M, GZ25-2A8-M, GZ5-2A8-M, GZL52A8-M, GZ25-3C8-M, GZ5-3C8-M, GZL53C8-M, GZ25-3G8-M, GZ5-3G8-M, GZL53G8-M, GZ25-4H88-M, GZ5-4H88-M, GZL54H88-M, GZ28-2A3-M, GZ8-2A3-M, GZL82A3-M, GZ28-3C3-M, GZ8-3C3-M, GZL83C3-M, GZ28-3G3-M, GZ8-3G3-M, GZL83G3-M, GZ28-4H8-M, GZ8-4H8-M, GZL84H8-M, GZ28-2A6-M, GZ8-2A6-M, GZL82A6-M, GZ28-2A8-M, GZ8-2A8-M, GZL82A8-M, GZ28-3C8-M, GZ8-3C8-M, GZL83C8-M, GZ28-3G8-M, GZ8-3G8-M, GZL83G8-M, GZ28-4H88-M, GZ8-4H88-M, GZL84H88-M, GZ26-3-M, GZ6-3F-M, GZL63-M, GZ35-6-M, GZ15-6-M, GZL156-M, GZ27-6-M, GZ7-6-M, GZL76-M, GZ34-6-M, GZ14-6-M, GZL146-M, GZ56-2L3-M, GZ36-2L3-M, GZL36L3-M, GZ59-3R6-M, GZ39-3R6-M, GZL39R6-M, GZ57-3C6-M, GZ37-3C6-M, GZL37C6-M, GZ58-3L6-M, GZ38-3L6-M, GZL38L6-M, GZDS25-3232-M, GZDS5-3232-M, GZLDS5-3232-M, GZDS25-3240-M, GZDS5-3240-M, GZLDS5-3240-M, GZDS25-3263-M, GZDS5-3263-M, GZLDS5-3263-M, GZDS25-4232-M, GZDS5-4232-M, GZLDS5-4232-M, GZDS25-4240-M, GZDS5-4240-M, GZLDS5-4240-M, GZDS25-4263-M, GZDS5-4263-M, GZLDS5-4263-M

Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at http://ul.com/aboutul/locations/

CERTIFICATE OF COMPLIANCE

Certificate Number	20191107-E12379
Report Reference	E12379-20191015
Issue Date	2019-NOVEMBER-07

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Standard(s) for Safety: UL 1203 - Explosion-Proof and Dust-Ignition-Proof Electrical Equipment for Use in Hazardous (Classified) Locations.

CAN/CSA C22.2 No. 30-M1986 - Explosion-Proof Enclosures for Use in Class I Hazardous Locations. Reaffirmed 2016

CAN/CSA C22.2 No. 25-1966 - Enclosures for Use in Class II Groups E, F, and G Hazardous Locations. Reaffirmed 2014.

UL 50 - Enclosures for electrical equipment

UL 508 & CSA C22.2 no. 14-13 - Standard for industrial control equipment

CSA C22.2 no. 94-M91 - Special purpose enclosures industrial product



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at http://ul.com/aboutul/locations/

CERTIFICATE OF COMPLIANCE

Certificate Number	20191107-E12379
Report Reference	E12379-20191015
Issue Date	2019-NOVEMBER-07
Issued to:	KILLARK, DIV OF HUBBELL INC (DELAWARE) 2112 FENTON LOGISTICS PARK BLVD FENTON, MO 63026 USA
This certificate confirms that representative samples of	AUXILIARY DEVICES FOR USE IN HAZARDOUS LOCATIONS Please see Addendum for Models
	Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.
Standard(s) for Safety:	Please see Addendum for Standards for Safety
Additional Information:	See the UL Online Certifications Directory at https://iq.ulprospector.com for additional information.

This *Certificate of Compliance* does not provide authorization to apply the UL Mark. Only the UL Follow-Up Services Procedure provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.

Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at http://ul.com/aboutul/locations/

CERTIFICATE OF COMPLIANCE

Certificate Number	20191107-E12379
Report Reference	E12379-20191015
Issue Date	2019-NOVEMBER-07

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Industrial Control Devices, for Use in Class I, Division 1, Groups B, C, and D; Class II, Division 1, Groups E, F and G; Class III; Hazardous (Classified) Locations, Models GZ21-RZ3, GZ21-GZ3, GZ21-KZ3, GZ21-AZ3, GZ21-WZ3, GZ21-BZ3, GZ1-RX3, GZ1-GX3, GZ1-KX3, GZ1-AX3, GZ1-WX3, GZ1-BX3, GZL1R3, GZL1G3, GZL1K3, GZL1A3, GZL1W3, GZL1B3, GZ21B-RZ3, GZ21B-GZ3, GZ21B-KZ3, GZ21B-AZ3, GZ21B-WZ3, GZ21B-BZ3, GZ1B-RX3, GZ1B-GX3, GZ1B-KX3, GZ1B-AX3, GZ1B-WX3, GZ1B-BX3, GZLB1R3, GZLB1G3, GZLB1K3, GZLB1A3, GZLB1W3, GZLB1B3, GZ23-G23, GZB3-G23, GZL3G23, GZ23-R23, GZB3-R23, GZL3R23, GZ23-A23, GZB3-A23, GZL3A23, GZ23-C23, GZB3-C23, GZL3C23, GZ23-B23, GZB3-B23, GZL3B23, GZ23-G4, GZB3-G4, GZL3G4, GZ23-R4, GZB3-R4, GZL3R4, GZ23-A4, GZB3-A4, GZL3A4, GZ23-C4, GZB3-C4, GZL3C4, GZ23-B4, GZB3-B4, GZL3B4, GZ23-G24, GZB3-G24, GZL3G24, GZ23-R24, GZB3-R24, GZL3R24, GZ23-A24, GZB3-A24, GZL3A24, GZ23-C24, GZB3-C24, GZL3C24, GZ23-B24, GZB3-B24, GZL3B24, GZMM21-RY3, GZMM1-RY3, GZMML-RY3, GZMM21-RG3, GZMM1-RG3, GZMML-RG3, GZMM21-RB3, GZMM1-RB3, GZMML-RB3, GZMP21-RM3, GZMP1-RM3, GZMPL1R3, GZMP21-GM3, GZMP1-GM3, GZMPL1G3, GZMP21-KM3, GZMP1-KM3, GZMPL1K3, GZMT21-RM3, GZMT1-RM3, GZMTL1R3, GZMK21-RM3, GZMK1-RM3, GZMKL1R3, GZK21-3, GZK1-3, GZKL13, GZ24-G233, GZB4-G233, GZL4G233, GZ24-R233, GZB4-R233, GZL4R233, GZ24-A233, GZB4-A233, GZL4A233, GZ24-B233, GZB4-B233, GZL4B233, GZ24-C233, GZB4-C233, GZL4C233, GZ24-G43, GZB4-G43, GZL4G43, GZ24-R43, GZB4-R43, GZL4R43, GZ24-A43, GZB4-A43, GZL4A43, GZ24-B43, GZB4-B43, GZL4B43, GZ24-C43, GZB4-C43, GZL4C43, GZ24-G243, GZB4-G243, GZL4G243, GZ24-R243, GZB4-R243, GZL4R243, GZ24-A243, GZB4-A243, GZL4A243, GZ24-B243, GZB4-B243, GZL4B243, GZ24-C243, GZB4-C243, GZL4C243, GZ25-2A3, GZ5-2A3, GZL52A3, GZ25-3C3, GZ5-3C3, GZL53C3, GZ25-3G3, GZ5-3G3, GZL53G3, GZ25-4H8, GZ5-4H8, GZL54H8, GZ25-2A6, GZ5-2A6, GZL52A6, GZ25-2A8, GZ5-2A8, GZL52A8, GZ25-3C8, GZ5-3C8, GZL53C8, GZ25-3G8, GZ5-3G8, GZL53G8, GZ25-4H88, GZ5-4H88, GZL54H88, GZ28-2A3, GZ8-2A3, GZL82A3, GZ28-3C3, GZ8-3C3, GZL83C3, GZ28-3G3, GZ8-3G3, GZL83G3, GZ28-4H8, GZ8-4H8, GZL84H8, GZ28-2A6, GZ8-2A6, GZL82A6, GZ28-2A8, GZ8-2A8, GZL82A8, GZ28-3C8, GZ8-3C8, GZL83C8, GZ28-3G8, GZ8-3G8, GZL83G8, GZ28-4H88, GZ8-4H88, GZL84H88, GZ26-3, GZ6-3, GZL63, GZ35-6, GZ15-6, GZL156, GZ27-6, GZ7-6, GZL76, GZ34-6, GZ14-6, GZL146, GZ56-2L3, GZ36-2L3, GZL36L3, GZ59-3R6, GZ39-3R6, GZL39R6, GZ57-3C6, GZ37-3C6, GZL37C6, GZ58-3L6, GZ38-3L6, GZL38L6, GZDS25-3232, GZDS5-3232, GZLDS5-3232, GZDS25-3240, GZDS5-3240, GZLDS5-3240, GZDS25-3263, GZDS5-3263, GZLDS5-3263, GZDS25-4232, GZDS5-4232, GZLDS5-4232, GZDS25-4240, GZDS5-4240, GZLDS5-4240, GZDS25-4263, GZDS5-4263, GZLDS5-4263, GZ21-RZ3-M, GZ21-GZ3-M, GZ21-KZ3-M, GZ21-AZ3-M, GZ21-WZ3-M, GZ21-BZ3-M, GZ1-RX3-M, GZ1-GX3-M, GZ1-KX3-M, GZ1-AX3-M, GZ1-WX3-M, GZ1-BX3-M, GZL1R3-M, GZL1G3-M, GZL1K3-M, GZL1A3-M, GZL1W3-M, GZL1B3-M, GZ21B-RZ3-M, GZ21B-GZ3-M, GZ21B-KZ3-M, GZ21B-AZ3-M, GZ21B-WZ3-M, GZ21B-BZ3-M, GZ1B-RX3-M, GZ1B-GX3-M, GZ1B-KX3-M, GZ1B-AX3-M, GZ1B-WX3-M,

Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at http://ul.com/aboutul/locations/

CERTIFICATE OF COMPLIANCE

Certificate Number	20191107-E12379
Report Reference	E12379-20191015
Issue Date	2019-NOVEMBER-07

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Industrial Control Devices, for Use in Class I, Division 1, Groups B, C, and D; Class II, Division 1, Groups E, F and G; Class III; Hazardous (Classified) Locations, Models GZ1B-BX3-M, GZLB1R3-M, GZLB1G3-M, GZLB1K3-M, GZLB1A3-M, GZLB1W3-M, GZLB1B3-M, GZ23-G23-M, GZB3-G23-M, GZL3G23-M, GZ23-R23-M, GZB3-R23-M, GZL3R23-M, GZ23-A23-M, GZB3-A23-M, GZL3A23-M, GZ23-C23-M, GZB3C23-M, GZL3C23-M, GZ23-B23-M, GZB3-B23-M, GZL3B23-M, GZ23-G4-M, GZB3-G4-M, GZL3G4-M, GZ23-R4-M, GZB3-R4-M, GZL3R4-M, GZ23-A4-M, GZB3-A4-M, GZL3A4-M, GZ23-C4-M, GZB3-C4-M, GZL3C4-M, GZ23-B4-M, GZB3-B4-M, GZL3B4-M, GZ23-G24-M, GZB3-G24-M, GZL3G24-M, GZ23-R24-M, GZB3-R24-M, GZL3R24-M, GZ23-A24-M, GZB3-A24-M, GZL3A24-M, GZ23-C24-M, GZB3-C24-M, GZL3C24-M, GZ23-B24-M, GZB3-B24-M, GZL3B24-M, GZMM21-RY3-M, GZMM1-RY3-M, GZMML-RY3-M, GZMM21-RG3-M, GZMM1-RG3-M, GZMML-RG3-M, GZMM21-RB3-M, GZMM1-RB3-M, GZMML-RB3-M, GZMP21-RM3-M, GZMP1-RM3-M, GZMPL1R3-M, GZMP21-GM3-M, GZMP1-GM3-M, GZMPL1G3-M, GZMP21-KM3-M, GZMP1-KM3-M, GZMPL1K3-M, GZMT21-RM3-M, GZMT1-RM3-M, GZMTL1R3-M, GZMK21-RM3-M, GZMK1-RM3-M, GZMKL1R3-M, GZK21-3-M, GZK1-3-M, GZKL13-M, GZ24-G233-M, GZB4-G233-M, GZL4G233-M, GZ24-R233-M, GZB4-R233-M, GZL4R233-M, GZ24-A233-M, GZB4-A233-M, GZL4A233-M, GZ24-B233-M, GZB4-B233-M, GZL4B233-M, GZ24-C233-M, GZB4-C233-M, GZL4C233-M, GZ24-G43-M, GZB4-G43-M, GZL4G43-M, GZ24-R43-M, GZB4-R43-M, GZL4R43-M, GZ24-A43-M, GZB4-A43-M, GZL4A43-M, GZ24-B43-M, GZB4-B43-M, GZL4B43-M, GZ24-C43-M, GZB4-C43-M, GZL4C43-M, GZ24-G243-M, GZB4-G243-M, GZL4G243-M, GZ24-R243-M, GZB4-R243-M, GZL4R243-M, GZ24-A243-M, GZB4-A243-M, GZL4A243-M, GZ24-B243-M, GZB4-B243-M, GZL4B243-M, GZ24-C243-M, GZB4-C243-M, GZL4C243-M, GZ25-2A3-M, GZ5-2A3-M, GZL52A3-M, GZ25-3C3-M, GZ5-3C3-M, GZL53C3-M, GZ25-3G3-M, GZ5-3G3-M, GZL53G3-M, GZ25-4H8-M, GZ5-4H8-M, GZL54H8-M, GZ25-2A6-M, GZ5-2A6-M, GZL52A6-M, GZ25-2A8-M, GZ5-2A8-M, GZL52A8-M, GZ25-3C8-M, GZ5-3C8-M, GZL53C8-M, GZ25-3G8-M, GZ5-3G8-M, GZL53G8-M, GZ25-4H88-M, GZ5-4H88-M, GZL54H88-M, GZ28-2A3-M, GZ8-2A3-M, GZL82A3-M, GZ28-3C3-M, GZ8-3C3-M, GZL83C3-M, GZ28-3G3-M, GZ8-3G3-M, GZL83G3-M, GZ28-4H8-M, GZ8-4H8-M, GZL84H8-M, GZ28-2A6-M, GZ8-2A6-M, GZL82A6-M, GZ28-2A8-M, GZ8-2A8-M, GZL82A8-M, GZ28-3C8-M, GZ8-3C8-M, GZL83C8-M, GZ28-3G8-M, GZ8-3G8-M, GZL83G8-M, GZ28-4H88-M, GZ8-4H88-M, GZL84H88-M, GZ26-3-M, GZ6-3F-M, GZL63-M, GZ35-6-M, GZ15-6-M, GZL156-M, GZ27-6-M, GZ7-6-M, GZL76-M, GZ34-6-M, GZ14-6-M, GZL146-M, GZ56-2L3-M, GZ36-2L3-M, GZL36L3-M, GZ59-3R6-M, GZ39-3R6-M, GZL39R6-M, GZ57-3C6-M, GZ37-3C6-M, GZL37C6-M, GZ58-3L6-M, GZ38-3L6-M, GZL38L6-M, GZDS25-3232-M, GZDS5-3232-M, GZLDS5-3232-M, GZDS25-3240-M, GZDS5-3240-M, GZLDS5-3240-M, GZDS25-3263-M, GZDS5-3263-M, GZLDS5-3263-M, GZDS25-4232-M, GZDS5-4232-M, GZLDS5-4232-M, GZDS25-4240-M, GZDS5-4240-M, GZLDS5-4240-M, GZDS25-4263-M, GZDS5-4263-M, GZLDS5-4263-M

Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at http://ul.com/aboutul/locations/

CERTIFICATE OF COMPLIANCE

Certificate Number	20191107-E12379
Report Reference	E12379-20191015
Issue Date	2019-NOVEMBER-07

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Standard(s) for Safety: UL 1203 - Explosion-Proof and Dust-Ignition-Proof Electrical Equipment for Use in Hazardous (Classified) Locations.

CAN/CSA C22.2 No. 30-M1986 - Explosion-Proof Enclosures for Use in Class I Hazardous Locations. Reaffirmed 2016

CAN/CSA C22.2 No. 25-1966 - Enclosures for Use in Class II Groups E, F, and G Hazardous Locations. Reaffirmed 2014.

UL 50 - Enclosures for electrical equipment

UL 508 & CSA C22.2 no. 14-13 - Standard for industrial control equipment

CSA C22.2 no. 94-M91 - Special purpose enclosures industrial product



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at http://ul.com/aboutul/locations/

Certification

Manufacturer: Larson Electronics LLC
Address: 9419 US-HWY 175
Kemp, Texas 75143

Declare the following equipment conforms to the standard(s) as listed:

Model: EPCS-PL-LED Series
Description: Explosion Proof Pilot Lights

Evaluated Listings:

CE: DIRECTIVE 2014/35/EU - LOW VOLTAGE DIRECTIVE
CE: DIRECTIVE 2014/30/EU - EMC DIRECTIVE
CE: Regulation (EC) No 1907/2006 - REACH REGULATION
CE: DIRECTIVE 2015/863/EU - ROHS DIRECTIVE

The EPCS-PL-LED Series complies with the essential protection requirements of the European Parliament of the Council Directive for Low Voltage Directive, EMC Directive, REACH Regulation, and RoHS Directive. This certification applies to all specimens manufactured in accordance to the manufacture's drawings.

Signed for and on behalf of: Larson Electronics, LLC
Place of issue: Kemp, TX

Signature: James Thomas

Name: James Thomas
Position: Operations Manager

LARSON ELECTRONICS LLC • 9419 E US HWY 175 • KEMP, TX 75143
p: 1-800-369-6671 • intl: 903-498-3363 • f: 903-498-3364 • sales@larsonelectronics.com

Certification

Manufacturer: Larson Electronics LLC
Address: 9419 US-HWY 175
Kemp, Texas 75143

Declare the following equipment conforms to the standard(s) as listed:

Model: EPCS-PL-LED Series
Description: Explosion Proof Pilot Lights

Evaluated Listings:

CE: DIRECTIVE 2015/863/EU - ROHS DIRECTIVE

This is to certify that products offered by Larson Electronics LLC comply with the Reduction of Hazardous Substances (RoHS) directives. Directive 2002/95/EC became effective on 1 July 2006. It restricts the use of six substances in the manufacture of electrical and electronic equipment. This directive was revised in June 2011 and is now referred to as directive 2011/65/EU. Directive 2015/863/EU amending Annex II to Directive 2011/65/EU announced plans to add four substances from 22 July 2019.

We hereby certify that the equipment specified above conforms to the Directive(s) by containing less of the restricted substances than the stated limits.

Signed for and on behalf of: Larson Electronics, LLC
Place of issue: Kemp, TX

Signature: James Thomas

Name: James Thomas
Position: Operations Manager

LARSON ELECTRONICS LLC • 9419 E US HWY 175 • KEMP, TX 75143
p: 1-800-369-6671 • intl: 903-498-3363 • f: 903-498-3364 • sales@larsonelectronics.com

Certification

Manufacturer: Larson Electronics LLC
Address: 9419 US-HWY 175
Kemp, Texas 75143

Declare the following equipment conforms to the standard(s) as listed:

Model: EPCS-PL-LED Series
Description: Explosion Proof Pilot Lights

Evaluated Listings:

CE: Regulation (EC) No 1907/2006 - REACH REGULATION

This letter establishes the opinion of Larson Electronics LLC regarding the status, under the current European Union ("EU") Regulations on Registration, Evaluation, Authorization, and Restriction of Chemical Substances ("REACH").

REACH does not apply to manufactured products which are referred to as "completed articles". Substances (chemicals) are subject to REACH registration, NOT products.

In addition, Articles are exempt from the REACH requirements if (a) the Article does not contain a substance of very high concern or candidate substance in an amount exceeding 0.1% weight by weight, and (b) if substances present in the Article in excess of 1 ton per year per importer are not expected nor intended to be released.

Based on communication with our raw material suppliers, we conclude that to the best of our knowledge our products requiring REACH compliance do not contain any of the currently listed SVHC in concentrations of 0.1% or above.

Accordingly, we foresee no registration or pre-registration requirement for the products we supply.

Signed for and on behalf of: Larson Electronics, LLC
Place of issue: Kemp, TX

Signature: James Thomas

Name: James Thomas
Position: Operations Manager

LARSON ELECTRONICS LLC • 9419 E US HWY 175 • KEMP, TX 75143
p: 1-800-369-6671 • intl: 903-498-3363 • f: 903-498-3364 • sales@larsonelectronics.com

Certification

Manufacturer: Larson Electronics LLC
Address: 9419 US-HWY 175
Kemp, Texas 75143

Declare the following equipment conforms to the standard(s) as listed:

Model: EPCS-PL-LED Series
Description: Explosion Proof Pilot Lights

Evaluated Listings:

FCC: Radio Frequency Emission & Authorization Status

The EPCS-PL-LED Series of Explosion Proof Pilot Lights comply with Federal Communications Commission requirements for Radio Frequency Emission & Authorization Status. This product is not capable of emitting rf energy and does not require FCC authorization. This certification applies to all specimens manufactured in accordance to the manufacture's drawings.

Signed for and on behalf of: Larson Electronics, LLC
Place of issue: Kemp, TX

Signature: James Thomas

Name: James Thomas
Position: Operations Manager

LARSON ELECTRONICS LLC • 9419 E US HWY 175 • KEMP, TX 75143
p: 1-800-369-6671 • intl: 903-498-3363 • f: 903-498-3364 • sales@larsonelectronics.com

Frequently Asked Questions (FAQ)