

Wiring Diagram

WARNING: *DO NOT SERVICE WHILE ENERGIZED!*

MT-DOE16-3P-415D-30KVA-240D.120CT-N3R-50HZ



COIL TAP ARRANGEMENT



PRIMARY VOLTS	
CONNECT LINES TO H1, H2, H3	
TAP	VOLTAGE
2	421
3	415
4	400
5	389
6	381
7	371
8	360

SECONDARY VOLTS	
CONNECT LINES	VOLTAGE
X1, X2, X3	240
X1-X4 OR X2-X4	120

LARSON ELECTRONICS LLC • 9419 E US HWY 175 • KEMP, TX 75143
p: 1-800-369-6671 • intl: 903-498-3363 • f: 903-498-3364 • sales@larsonelectronics.com