
REV	DESCRIPTION	DATE
A	PRODUCTION RELEASE	7/17/2023

MPD-CW1-82.60IG-DE45YT-GZ-6.D15-4.L04-2.N10-M1

LARSON ELECTRONICS®




LARSON ELECTRONICS

9419 E US HWY 175,
KEMP, TX 75143

TITLE: MPD-CW1-82.60IG-DE45YT-GZ -6.D15-4.L04-2.N10-M1

DRAWN BY	DATE	REV
S.Desai	07-17-2023	A
CHECKED BY	SHEET #	DRAWING #
J.Maldonado	1 OF 3	101




LARSON ELECTRONICS

9419 E US HWY 175,
KEMP, TX 75143

TITLE

MPD-CW1-82.60IG-DE45YT-GZ
-6.D15-4.L04-2.N10-M1

DRAWN BY	DATE	REV
S.Desai	07-17-2023	A
CHECKED BY	SHEET #	DRAWING #
J.Maldonado	2 OF 3	102



TAGS	QTY	CATALOG	DESCRIPTION
J3-103.26 J3-103.35	2		1P 120V 20A 5-20R SMART LOCKI SOLATED GROUND GFCI RECEPTACLE
J2-102.102A J2-102.93 J3-103.08 J3-103.17	4		1P 120V 20A L5-20R LOCKING RECEPTACLE ISOLATED GROUND ORANGE
P1-101.48	1	UNV00013942C	GROUND BAR KIT
P1-101.13	1		3PH 480/277VAC 60A PIN AND SLEEVE INLET UL 1682
J2-102.08 J2-102.21 J2-102.34 J2-102.47 J2-102.67 J2-102.80	6		3PH 208/120V 100A 3P+N+G PIN AND SLEEVE RECEPTACLE UL1682
CB2-102.08 CB2-102.21 CB2-102.34 CB2-102.47 CB2-102.67 CB2-102.80	6	UNV00014728	3P 480V 60 A DIN RAIL MOUNT MCCB
CB1-101.13	1	UNV00015180	3P 60A 480V UL489 MCCB
CB3-103.26 CB3-103.35	2	UNV00017491	1P 125V 20A 10KA UL489 DIN RAIL MOUNT BREAKER
CB2-102.102 CB2-102.93 CB3-103.08 CB3-103.17	4	UNV00019330	1P+1N 120V 20A DIN RAIL MOUNT GROUND FAULT CIRCUIT BREAKER UL1053
P1-101.37 PD_1-101.32 PD_1-101.32A PD_1-101.32B PD_1-101.32C	5	UNV00015085	POWER DISRIBUTION BLOCK 2-12 OPENING 570A
XF1-101.17	1	UNV00014228	45 KVA 480D- 208V.120V SECONDARY 60 HZ NEMA 3R

LARSON ELECTRONICS

9419 E US HWY 175,
KEMP, TX 75143

TITLE: MPD-CW1-82.60IG-DE45YT-GZ -6.D15-4.L04-2.N10-M1

DRAWN BY	DATE	REV
S.Desai	07-17-2023	A
CHECKED BY	SHEET #	DRAWING #
J.Maldonado	3 OF 3	103