


REV	DESCRIPTION	DATE
A	PDU CREATE	12-26-2024

MPD-SA4-TL.150AF-YT0-Z-5.CLR5- 6.L37-1.Q4-R1






LARSON
ELECTRONICS

9419 E US HWY 175,
KEMP, TX 75143

TITLE
MPD-SA4-TL.150AF-YT0-Z-5.CLR5-
6.L37-1.Q4-R1

DRAWN BY	DATE	REV
D. DOWNS	12-26-2024	A
CHECKED BY	SHEET #	DRAWING #
	1 OF 3	101





**LARSON
ELECTRONICS**

9419 E US HWY 175,
KEMP, TX 75143

MPD-SA4-TL,150AF-YT0-Z-5,CLR5-6L37-1,Q4-R1		
DRAWN BY D. DOWNS	DATE 12-26-2024	REV A
CHECKED BY	SHEET # 2 OF 3	DRAWING # 102

TAGS	QTY	CATALOG	DESCRIPTION
DB-101,37 DB-101,37A DB-101,37B DB-101,37C	3	UNV00016633	POWER DISTRIBUTION BLOCK 1-5 OPENING 300A 600V
DM1-101,12	1	UNV00016483	1-3PH 100-277V POWER METER POSITIVE LCD PANEL MOUNT
CT1-101,26 CT1-101,29 CT1-101,32	3	CTF-SSFT-0200	200A TO 5A SOLID CORE 1.56" DIA. SENSING WINDOW AC CURRENT TRANSFORMER PANEL MOUNT
FBI	4	UNV00018372	30A 1P 600V UL 18-BAWG CLASS CC FUSE HOLDER DIN RAIL MOUNT
FU1-101,02 FU1-101,14 FU1-101,17 FU1-101,20	4	LP-CC-12	0.5A 600V CLASS CC TIME DELAY MIDGET FUSE
P1-101,48	1	UNV00013942C	GROUND BAR KIT 14 AWG TO 4 AWG
J1-101,25	1	UNV00013729	150A 600V 8-AWG MALE PANEL RECEPTACLE CAM LOCK-BLACK
J1-101,28	1	UNV00013730	150A 600V 8-AWG MALE PANEL RECEPTACLE CAM LOCK-RED
J1-101,31	1	UNV00013731	150A 600V 8-AWG MALE PANEL RECEPTACLE CAM LOCK-BLUE
J1-101,34	1	UNV00003273	150A 600V 8-AWG MALE PANEL RECEPTACLE CAM LOCK-WHITE
J1-101,37	1	UNV00006704	150A 600V 8-AWG MALE PANEL RECEPTACLE CAM LOCK-GREEN
CB2-102,19 CB2-102,30 CB2-102,41 CB2-102,64 CB2-102,75 CB2-102,86	6	UNV00015171	30A 3P 250V 10KAIC UL489 DIN RAIL MOUNT BREAKER
J2-102,19 J2-102,30 J2-102,41 J2-102,64 J2-102,75 J2-102,86	6	UNV00007119	L21-30R 4P5W 30A 208Y/120V NEMA TWIST-LOCK RECEPTACLE

 LARSON ELECTRONICS 8419 E US HWY 175, KEMP, TX 75143	TITLE MPD-SA4-TL,150AF-YT0-Z-5,CLR5-6,L37-1,Q4-R1		
	DRAWN BY D. DOWNS	DATE 12-26-2024	REV A
	CHECKED BY	SHEET # 3 OF 3	DRAWING # 103