
REV	DESCRIPTION	DATE
A	QUOTE	02/06/2026

MPD-CD1-862.30AB-DE15SZ-DG-U5.C04-U3.L09-U2.N09-M1


LARSON ELECTRONICS®



LARSON ELECTRONICS

9419 E US HWY 175,
KEMP, TX 75143

TITLE		
MPD-CD1-862.30AB-DE15SZ-DG-U5.C04-U3.L09-U2.N09-M1		
DRAWN BY: L.Calib	DATE: 02-06-2026	REV: A
CHECKED BY:	SHEET #: 1 OF 3	DRAWING #: 101



LARSON ELECTRONICS

9419 E US HWY 175,
KEMP, TX 75143

TITLE: MPD-CD1-862.30AB-DE15SZ-DG-U5.C04-U3.L09-U2.N09-M1			
DRAWN BY: L.Calib	DATE: 02-06-2026	REV: A	
CHECKED BY:	SHEET #: 2 OF 3	DRAWING #: 102	

TAGS	QTY	CATALOG	DESCRIPTION
PL1-101.08	1	UNV00002358	30A 3W 4P ACP3034BC PLUG
J2-102.07 J2-102.16	2	UNV00012694	5-20R 125V 20A DUPLEX RECEPTACLE
J1-101.25	1	UNV00008818	CS6369 50A 250V 3P RECEPTACLE
J1-101.38	1	UNV00007127	L6-30R TURN LOCK 250V 30 AMP RECEPTACLE
2 HOLE GRND LUG	1	UNV00007136	2 HOLE GROUND LUG
CB1-101.38	1	UNV00016407	2P 30A125/250V DIN RAIL GFI BREAKER
CB1-101.25	1	UNV00008973	QBGFT2050 2P 50A Bolt On Ground Fault Circuit Breaker
CB1-101.08A	1	UNV00015180	3P 60A 600V UL489 MCCB
CB2-102.07 CB2-102.16	2	UNV00019330	1P+1N 120V 20A DIN RAIL MOUNT GROUND FAULT CIRCUIT BREAKER UL1053
CB1-101.08	1	UNV00015172	3P 30A 240/480VAC MCCB
PD 1 PD 2 PD 3	3	UNV00015084	POWER DISTRIBUTION BLOCK 175 A 600V 1-4 OPENING
GRND BAR KIT	1	UNV00013942C	GROUND BAR KIT
CBL1-101.08	1	UNV000007449	8/4 AWG SOOW CORD
XF1-101.11	1	UNV00008870	15KVA 240/480V -120/240V 1PH N3R TRANSFORMER

LARSON ELECTRONICS
9419 E US HWY 175,
KEMP, TX 75143

TITLE
MPD-CD1-862.30AB-DE15SZ-DG-U5.C04-U3.L09-U2.N09-M1

DRAWN BY	DATE	REV
L.Calib	02-06-2026	A
CHECKED BY	SHEET #	DRAWING #
	3 OF 3	103